

SECTION 1000 PARKS AND RECREATION CONSTRUCTION

<u>SECTION</u>	<u>PAGE</u>
1001.00 PLAN SUBMITTALS	6
1001.01 Notification Prior To Digging.....	6
1001.02 All Plans.....	6
1001.03 Landscape Plans.....	6
1001.04 Irrigation Plans.....	7
1002.00 PRE-CONSTRUCTION MEETING REQUIRED.....	8
1010.00 SITE PREPARATION	9
1011.00 General.....	9
1012.00 Protection of Existing Vegetation.....	9
1012.01 Protection of Existing Vegetation on Town Owned Properties.....	9
1012.02 Existing and Native Vegetation Representation	9
1012.03 Protective Fencing	10
1012.04 Signage.....	10
1012.05 Prohibited Practices in Vegetation and Tree Protection Zones	10
1012.06 Vegetation Protection Zones.....	10
1012.07 Tree Protection Zones	10
1012.08 Tunneling and Boring	11
1012.09 Soil Protection.....	11
1012.10 Penalties	11
1012.11 Maintenance of Retained Trees	11
1020.00 TOPSOIL PREPARATION	11
1021.00 General.....	12
1021.01 Soil Test	12
1022.00 Materials	13
1022.01 Organic Materials	13
1022.02 Fertilizer for Parks or Conventional Landscape Areas.....	13
1022.03 Fertilizer for Open Space and Native Seeded Areas.....	13
1023.00 Process (Seedbed preparation)	13
1023.01 Seedbed Prep Process for Parks or Other Conventional Landscape Areas	13
1023.02 Seedbed Preparation Process for Open Space and Native Seeded Areas	14
1023.03 Annual Weed Removal Procedure.....	14
1023.04 Organic Matter for Native Seeded Areas.....	14
1024.00 Inspections	14
1024.01 Materials Inspection.....	15
1024.02 Soil Preparation Inspection.....	15
1030.00 SEEDING SPECIFICATIONS.....	15
1031.00 General.....	15

1032.00 Materials 15
1032.01 Topsoil 15
1032.02 Booster Fertilizer 16
1032.03 Bluegrass, Fine Fescue, Tall Fescue and Rhizomatous Tall Fescue Seed..... 16
1032.04 Native Seed 16
1032.05 Top-dressing/Mulch..... 17
1033.00 Seeding Process 17
1033.01 Bluegrass, Fine Fescue, Tall Fescue and Rhizomatous Tall Fescue Seeding.. 17
1033.02 Native Seeding..... 18
1034.00 Seeding Rates and Mixtures..... 20
1034.01 Bluegrass Seed Rate..... 21
1034.02 Tall Fescue and Rhizomatous Tall Fescue Seeding Rate 21
1034.03 Fine Fescue Seeding Rate 21
1034.04 Native Seed Rates and Mixtures 21
1034.05 Additional Seed Varieties 27
1035.00 Maintenance Procedures 28
1035.01 Maintenance Procedures for Bluegrass, Fine Fescue, Tall Fescue and/or
Rhizomatous Tall Fescue Grasses. 28
1035.02 Maintenance Procedures for Native and Open Space Areas 29
1036.00 Inspections 33
1036.01 Inspection of Seed Certifications 33
1036.02 Germination Inspection..... 33
1040.00 SODDING SPECIFICATIONS..... 33
1041.00 General..... 33
1042.00 Materials 33
1042.01 Topsoil 33
1042.02 Booster Fertilizer 33
1042.03 Sod 34
1043.00 Sodding Process..... 34
1043.01 Care and Handling 34
1043.02 Transporting Sod On-Site 34
1043.03 Sodding 34
1043.04 Sodding Inspections 35
1044.00 Cleanup 35
1045.00 Maintenance 35
1045.01 Mowing 35
1045.02 Additional Fertilizing..... 36
1045.03 Watering..... 36
1046.00 Landscape Inspections..... 36
1047.00 Landscape Warranty Period..... 36
1050.00 SPRINKLER SYSTEMS..... 37
1051.00 General..... 37
1051.01 Temporary Irrigation Systems 37

1051.02 Coverage 38

1051.03 Non-Potable Irrigation Systems 38

1052.00 Materials 38

1052.01 Water License and Tap Fee 38

1052.02 Water Tap 38

1052.03 Water Service Line 38

1052.04 Meter Pit 39

1052.05 Water Meter 39

1052.06 Electrical Service 39

1052.07 Backflow Preventer 39

1052.08 Booster Pump 40

1052.09 Pump House 40

1052.10 Controllers 40

1052.11 Zone Valves 41

1052.12 Heads 41

1052.13 Field Wiring 42

1052.14 Pipe 42

1052.15 Quick Coupler Valves 43

1052.16 Stop and Waste Valve 43

1052.17 Isolation Valves 43

1052.18 Pressure Reducing Valves 44

1052.19 Sleeving 44

1052.20 Drip Irrigation 44

1052.21 Fittings 45

1053.00 Site Conditions 45

1054.00 Excavation 46

1055.00 Process 46

1056.00 Inspections 47

1056.01 Sprinkler Location Staking 47

1056.02 Main Line Inspection 48

1056.03 Wiring Inspection 48

1056.04 Coverage Test 48

1056.05 Pressure Test 48

1057.00 Warranty Period 48

1060.00 PLANTING SPECIFICATIONS 49

1061.00 General 49

1062.00 Materials 49

1062.01 Wood and Rock Mulch 49

1062.02 Organic Amendments 50

1062.03 Landscape Fabric 50

1062.04 Edging 50

1062.05 Staking and Guying 50

1062.06 Submittals 50

1062.07 Trees and Shrubs 50

1063.00 Plant and Tree Handling, Transportation, and Storage 70

1064.00 Planting 71

1064.01 Location Staking 71

1064.02 Placement 71

1064.03 Placement of Native Trees and Shrubs in Native Areas 72

1064.04 Seasons of Planting 72

1064.05 Planting Procedures 72

1064.06 Staking and Guying 74

1064.07 Mulching 74

1064.08 Pruning 75

1064.09 Fertilizing 75

1065.00 Maintenance 75

1065.01 Pruning 75

1065.02 Replacements 76

1065.03 Fertilization 76

1065.04 Watering 76

1065.05 Staking 76

1065.06 Weeding 76

1065.07 Mulching 76

1068.00 Inspections 77

1068.01 Plant Location Staking 77

1068.02 Quantity and Quality of Plant Material 77

1068.03 Planting Operations 77

1069.00 Final Acceptance and Final Inspection 77

1070.00 PARK AMENITIES AND PLAYGROUND EQUIPMENT 77

1071.00 General 78

1072.00 Softball and Baseball Field Specifications 78

1072.01 Softball 78

1072.02 Baseball 78

1072.03 Sports Equipment 79

1073.00 Playground Equipment 80

1073.01 Proposal Submittals 80

1073.02 Accessibility Requirements 81

1073.03 Protective Ground Space Area 81

1073.04 Component Requirements 82

1073.05 Play Equipment 82

1073.06 Site Requirements 83

1073.07 Inspections 83

1073.08 Maintenance and Training 84

1073.09 Warranty 84

1074.00 Pocket Park Design Standards 84

1080.00 TRAILS, WALKWAYS AND MAINTENANCE PATHS 86

1081.00 Concrete Trails, Walkways and Maintenance Paths 86

1082.00 Soft Trails 86

1083.00 Trail Specifications 86

 1083.01 Location of Trails..... 86

 1083.02 Alignment of Trails..... 86

 1083.03 Width of Trail Corridor..... 87

1084.00 Types of Trails..... 87

 1084.01 Spine Trail..... 87

 1084.02 Local Trails 88

 1084.03 Primitive Trails 89

 1084.04 Trailheads..... 89

 1084.05 Waysides 90

 1084.06 Bridges 90

1090.00 PARKS AND TRAIL SIGN SPECIFICATIONS 90

1091.00 General..... 90

1092.00 Sign Types..... 91

 1092.01 Identification..... 91

 1092.02 Informational, Instruction and Interpretive..... 91

 1092.03 Regulatory..... 91

 1092.04 Way Finding..... 92

1093.00 Typefaces 92

1094.00 Color Palette..... 92

1095.00 Color Groupings by Type/Area 92

1096.00 Graphic Standards..... 92

1097.00 Fabricator Performance and Material Requirements 93

SECTION 1000 PARKS AND RECREATION CONSTRUCTION**1001.00 PLAN SUBMITTALS**

1001.01 Notification Prior To Digging

All parties wishing to install trees, shrubs, plants or other landscape materials **MUST** contact Colorado 811 and receive confirmation clearance prior to any project commencement.

1001.02 All Plans

All landscape and irrigation plans shall include the following components prior to submitting to the town for review:

- Name of project and address in title block
- Designer or firm name, address, and phone number
- Gross acreage
- Submittal date
- North arrow
- Vicinity map
- Plan scale (both written and graphic). Irrigation and Landscape plan must be drawn to the same scale.
- Sheets numbered with total preceded with “L” to denote landscape and “I” to denote irrigation. (Example: L1 of 8, L2 of 8, etc.) (Example: I1 of 5, I2 of 5, etc.)
- Existing and proposed easements showing type, location, and width
- Property, lot, and project boundary lines
- Existing and proposed topographical contour lines. Height and slope of all changes in elevation such as berms, swales, ditches, etc. shall be identified.
- Scalable plans shall be submitted in the size of 24”x 36” with half sets available on request
- Town of Erie Standard Landscape and Irrigation General Notes.

1001.03 Landscape Plans

All landscape plans shall include the following components if applicable prior to submitting to the town for review if applicable:

- Cloud, delta, and date all revisions to any plans previously reviewed by staff
- Existing and proposed lighting elements including locations and details
- Traffic and street signage locations and dimensions
- Existing and proposed above and below ground utilities and easements
- Existing and proposed driveways, sidewalks, trails, access roads to oil and gas facilities, parking areas, etc. locations and details. Label and specify surface materials and thickness. For parking lots, breakdown by types and number of vehicles
- Existing and proposed structures and dimensions

- Major site furnishings shall be identified (exterior signs, benches, water features, planters, walls, enclosures, bike racks, trash receptacles, sculptures, etc.) including locations, details, and legend
- Fencing materials including locations and details
- Plant materials list that specifies plant symbols, plant names (both botanical and common), legend of abbreviations, quantities, container or caliper sizes at time of installation, and root containment.
- Above and below ground planting pits, containers, and tree grate details
- Exploded views of densely vegetated areas or areas of great detail
- Existing vegetation to be retained or removed including sizes and species. Vegetation and Tree Protection Zones shall be included on all applicable landscape plans.
- Delineation of all corner sight triangles. Street trees shall be placed a minimum of fifty-five feet (55') from all intersections
- Labeled or keyed all areas of mulch and indicate type and square footage
- Labeled or keyed all areas to receive soil amendments
- Labeled locations of proposed turf species including information on method of installation (sod, plugs, seeding rate)
- Plans will provide detailed square feet/acreage measurements for all landscaped areas, as well as include all required organic materials as described within this Section.
- Grading: Grade elevations shall be marked preferably at either 1' or 2' contours, and no more than 5' contours. Slopes shall be preferred at 4:1 or gentler; 3:1 slopes are the steepest acceptable slopes and shall be minimized to the greatest extent possible. For trails, running slope shall equal 5% or less, and side slope shall equal 2% or less.

1001.04 Irrigation Plans

- All irrigation plans shall include the following components if applicable prior to submitting to the town for review:
- Cloud, delta, and date all revisions to any plans previously reviewed by staff
- Site specific conditions
- System component legend with clear, consistent symbols
- Symbols of other major components
- Type and size of main irrigation system components
- Sprinkler/emitter legend including symbols, operating pressure (PSI), flow rate (GPM)
- Backflow prevention unit location, size, and type and installed pursuant to applicable plumbing and local codes
- Submit a watering schedule with run times and application rates
- Static pressure and design pressure shall be provided
- Provide pressure loss calculations on request
- The point of connection (POC) shall indicate the location and size of meter
- Show and label locations to be irrigated with potable and non-potable water and identify the total square footage of each
- Number and type of irrigation system controllers

- Shut off and isolation valves
- Zone valves with locations, type, size, flow, and number
- Frequency of cycle for each control valve
- Turf and non-turf zones shall be irrigated on separate valves
- Show mains and laterals piping
- Show spray heads, location, and type
- Sprinkler heads must provide head to head water coverage
- No single zone shall mix head types
- Minimum acceptable distribution uniformities shall be 55% for pop up sprinkler heads or spray zones and 70% for rotor zones, or current irrigation association accepted minimums
- Indicate location and size (area) of each hydro-zone – including any zones using non-potable water, total water budget broken down by each hydro-zone, location and size of water tap and meter, existing and design water pressure, type of irrigation technique (such as drip, micro-spray, spray, rotor, underground, etc.), and other general information
- Irrigation zones substantially corresponding to hydro-zones on the landscape plan and labeled by precipitation rates and method of application
- Show and label locations of proposed (low, moderate, high) hydro-zones and identify the total square footage of each
- Total water budget and calculations by hydro-zone
- Design for berms and slopes should minimize runoff. (Berms and slopes may need repetitive, shorter watering cycles.)
- All systems shall be capable of supplying a sufficient number of inches of water per week to the total irrigated area in order to maintain the health of the plant material
- Sleeve all lines under hardscapes
- Install all temporary irrigation for Town-owned and maintained sites below ground.

1002.00 Pre-Construction Meeting Required

A pre-construction meeting, to be scheduled at a mutually agreeable time with staff from Parks & Recreation Department, the Public Works Department and all contractors. Agendas shall consist of the following agenda items:

1. Attendance Sheet (includes all contact and emergency contact information)
2. Introductions
3. Required Documentation (Permits, licensing needs, etc.)
4. Standards and Specifications
5. Utility Locates
6. Water Availability on Site, Hydrant Meter
7. Erosion and Tracking Controls (if needed)
8. Notice To Proceed

9. Project Scheduling

- a. Project Timeline (Includes weekly project update meetings-date, time, location)
- b. Work Hours
- 10. Safety
- 11. Rights of Way and Easements
- 12. Traffic Control (if needed)
- 13. Changes and Deviation From Approved Plans (Change Orders)
- 14. Daily and On-Going Inspections
- 15. Concrete Inspections (through Public Works)
- 16. Grade/Soil Prep/Sod and Seed Inspections
- 17. Irrigation, Water Tap, Backflow Inspection, Mainline Pressure Test, Irrigation Coverage Test
- 18. Tree Inspections, Tree Tagging
- 19. Plant Material-Sizes, Quality, etc.
- 20. Playground Inspections (if applicable)
- 21. Acceptance and Warranty Procedures
- 22. As Builts (requires one paper copy at minimum 24” by 36” size, Mylar set, CD)
- 23. Miscellaneous

1010.00 SITE PREPARATION

1011.00 General

Site preparation shall be completed in accordance with Section 1000.00, Site Work and Earthwork, of these STANDARDS AND SPECIFICATIONS.

Contractor will identify, verify and protect control point. Control point to be identified on all plans and as- builts. Contractor will verify location of control point weekly. Original condition of control point pin must be maintained throughout the entire project.

1012.00 Protection of Existing Vegetation

1012.01 Protection of Existing Vegetation on Town Owned Properties.

Prior to commencement of any site work, the Contractor, in conjunction with the Parks & Recreation Director or designee, shall identify all designated vegetation (or remnant native areas) suitable for preservation located on Town owned properties. Vegetation that is to be preserved on the site shall be protected by creating adequate Vegetation and Tree Protection Zones. Protective fencing and signage shall be placed along the perimeter of designated Vegetation and Tree Protection Zones.

1012.02 Existing and Native Vegetation Representation

All significant existing and native vegetation shall be depicted on the design plans prior to adopting any “approved” plans.

1012.03 Protective Fencing

Vegetation and Tree Protection Zones shall be protected by orange vinyl construction fencing, chain link fencing, or snow fencing at least (4) feet high and supported at (10) foot intervals by metal T-posts. Wooden stakes and rebar posts shall not be used as supports. Fencing shall be maintained upright and in place. All fencing shall be in place prior to commencement of any site work and remain in place until all work has been completed.

1012.04 Signage

All protective fencing shall have a waterproof vegetation protection sign affixed to the fence every (20) feet in such a manner to be clearly visible to workers on the site. Signage shall be maintained visible and legible. Signage shall be written in both Spanish and English and read as follows: “Protected Vegetation: NO traffic, vehicles, or material storage in this area.”

1012.05 Prohibited Practices in Vegetation and Tree Protection Zones

Prohibited practices within Vegetation and Tree Protection Zone(s) shall include, but not limited to the following: removal, relocation, or trimming of vegetation without permission of Parks & Recreation Director or designee; breaking of branches or scraping of the bark; changes to existing grade by excavating, filling, trenching, or use of augers; nailing, bolting, or using vegetation as a temporary support in any way; parking or storing equipment or building materials; dumping of construction waste or materials, disposing of liquids or contaminants; driving equipment through; or removal of protective fencing until all work has been completed.

1012.06 Vegetation Protection Zones

All vegetation types that have been deemed suitable for preservation, with the exception of trees, shall be adequately preserved in Vegetation Protection Zones. Protective fencing shall be placed a minimum of five (5) feet away from the edge of the vegetation’s canopy and encompass the entire plant species/community.

1012.07 Tree Protection Zones

The Contractor, in conjunction with the Parks & Recreation Director or designee, shall identify the critical root zone area by all of the trees that are to be preserved on the site and create adequate Tree Protection Zone(s). The critical root zone shall be determined by whichever encompasses the greatest area: (1) the irregular shape formed around a tree by a series of vertical lines that run through the outermost portion of the canopy of the tree and extend to the ground, often referred to as the drip line; or (2) one and a half (1 1/2) feet of space from the trunk for each inch of trunk

diameter in every direction. The critical root zone dimensions will serve as the required dimensions of the Tree Protection Zone.

1012.08 Tunneling and Boring

There shall be no trenching permitted within a Vegetation or Tree Protection Zone. Utilities shall be bored under the Vegetation or Tree Protection Zone in circumstances where it is not possible to trench around the protected area(s). When required, the length of the bore shall be the width of the critical root zone at a minimum depth of forty-eight (48) inches.

1012.09 Soil Protection

Under special circumstances, where vehicle and equipment access is needed through a Vegetation or Tree Protection Zone, permission must be obtained from the Parks & Recreation Director or designee. Any access roads through a Vegetation or Tree Protection Zone shall be created using six (6) inches of wood mulch to reduce soil compaction in areas subject to repeated construction traffic. The mulch shall be replenished as necessary to maintain a six (6) inch depth. Upon completion of all site work, the mulch shall be removed with care taken not to change existing grade.

1012.10 Penalties

Contractor shall be held responsible for any damage to vegetation that was designated to be preserved within designated Vegetation and Tree Protection Zones.

Failure to comply with Protection of Existing Vegetation specifications may result in penalties. If the violation results in damage to a tree or other woody plant, there shall be, in addition to any other applicable penalty, a penalty of three (3) times the damage caused to the tree or other woody plant, or \$500, whichever is greater. In the event a tree or other woody plant is removed in violation of any of the provisions of this section, the additional penalty shall be three (3) times the value of the tree. For purposes of calculating the damage to the tree, the most recent edition of the "Guide for Establishing Values of Trees and Other Plants" by the Council of Tree and Landscape Appraisers shall be presumed to provide the appropriate basis for determining damages.

1012.11 Maintenance of Retained Trees

All vegetation that was designated to be preserved within designated Vegetation and Tree Protection Zones shall be maintained by Contractor including watering and pruning until final acceptance has been granted.

1020.00 TOPSOIL PREPARATION

1021.00 General

The Contractor will provide all labor, equipment and materials necessary to complete the topsoil preparation for seeding and/or sodding as required by the accepted plans and these STANDARDS AND SPECIFICATIONS.

Areas to be developed or otherwise re-seeded (including native seeding areas which are currently weed dominated) which are infested with annual, biennial or perennial weeds, such as bindweed, Canadian thistle, Scotch thistle, Russian thistle, Kochia, Diffuse knapweed, or annual ryegrass, and not bearing significant remnant native species, shall be treated with Round-up or another generic Glyphosate based broad spectrum herbicide at a rate recommended on the chemical's label for controlling all existing vegetation. Do not treat remnant native grasses, shrubs or trees in designated open space areas. Do not till, reseed or plant herbicide treated areas for at least seven (7) days following treatment. More time may be needed to neutralize the herbicide in cold weather or on sandy soils. All applicable portions of Section 1032.01, Topsoil, of these STANDARDS AND SPECIFICATIONS shall apply.

Landscape plans must show amount of organic amendments needed at a rate of five (5) cu. yards per thousand (1000) square feet for all landscaped areas. Native areas soil amendments will be shown at a rate of three (3) cu. yards per thousand (1000) square feet. Plans will provide detailed square feet/acreage measurements for all landscaped areas.

1021.01 Soil Test

Contractor shall notify the Parks & Recreation Director or designee upon completion of rough grading and prior to commencement of soil preparation work. For parcels to be maintained by the Town of Erie, the Contractor shall obtain agronomic soils tests for all planting areas after completion of rough grading and prior to start of soil preparation work to determine what amendments and method of application are required to support trees, shrubs and groundcovers, seeds and sod identified on the landscaping plan. Tests shall be performed by an approved agronomic soils testing laboratory and shall include a fertility and suitability analysis with written recommendations for soil preparation, planting backfill mix, and post plant fertilization program. The soils report recommendations will take precedence over the minimum amendment and fertilizer application rates specified herein only if the soils report recommendations exceed the specified minimums.

- Soil tests shall include the following at a minimum:
- Particle size analysis of soil for percentage of sand, silt, and clay
- Chemical analysis, including the following:
 - pH and buffer pH
 - Percentage of organic content by oven-dried weight.
 - Nutrient levels by parts per million, including nitrogen, phosphorus, potassium, manganese, iron, zinc, and calcium. Nutrient test shall include the testing laboratory recommendations for supplemental additions to the soil based on the requirements of horticultural plants.

- Soluble salt by electrical conductivity of a 1:2, soil: water, sample measured in millimho per cm.
- Cation exchange capacity (CEC).

1022.00 Materials

1022.01 Organic Materials

Organic amendments shall be certified as “Class 1 Compost” and consist of an organic product containing a mixture of well-rotted/composted cow or sheep manure and or composted aspen humus or wood residue or approved equal (sphagnum or native mountain peat is not acceptable). Organic product shall have been aerobically and naturally processed in such a manner as to maintain a consistent temperature of 140 degrees Fahrenheit 30 degrees Celsius or greater for 70 to 90 days. The pH after composting shall be between 6.0 and 7.8, with dry organic matter content of not less than 30% and soluble salts not greater than 5mmhos/cm. Certification must be provided to prove the product has gone through this process.

1022.02 Fertilizer for Parks or Conventional Landscape Areas

Fertilizer will be a complete starter fertilizer having a ratio of approximately 5-15-1, with a minimum acceptable nitrogen level of 15%, and minimum acceptable Phosphorus level of 45%. An example is fertilizer with the chemical analysis of Nitrogen-18, Phosphorous-46, Potash-0. Fertilizer will be delivered to the site in new, unopened bags bearing the manufacturer’s name and the chemical analysis. Fertilizer will conform to all Colorado Department of Agriculture fertilizer laws.

1022.03 Fertilizer for Open Space and Native Seeded Areas

Forte Biosol or approved equal, a slow release organic fertilizer shall be applied to all native seeded areas at a minimum rate of eight hundred (800) pounds per acre. Forte Biosol shall be applied following seeding and before mulch application.

1023.00 Process (Seedbed preparation)

1023.01 Seedbed Prep Process for Parks or Other Conventional Landscape Areas

The Contractor will cultivate the area to be seeded / sodded to a depth of six (6) inches so as to free the site of weeds and other plants that may interfere with turf establishment. All stones, sticks, and debris brought to the surface over one and one-half inches (1.5”) diameter will be removed from the site. Prior to seeding / sodding, the Contractor will uniformly apply the specified Class 1 organic material at the rate of five (5) cubic yards per one thousand (1,000) square feet along with a complete starter fertilizer. An example is fertilizer having a ratio of approximately 5-15-1, with a minimum acceptable nitrogen level of 15%, and minimum acceptable Phosphorus level of 45%, at the rate of five (5) pounds per one thousand (1,000) square feet and incorporate both materials into the soil to a depth of six (6) inches with a disc, rototiller, or other suitable tilling equipment. Organic

materials shall be applied when the surface is within two (2) percent of final grade. No organic material containing manure shall be stockpiled on the site for more than eight (8) hours before it is incorporated into the soil. After tilling, the areas to be seeded or sodded will be raked, graded, and rolled to the desired finished grades according to the grading plan within a tolerance of one-tenth (0.1) foot, with gently sloping surfaces to adequately drain all surface water run-off. The finished surface will be even and uniform, and no dirt clumps or other debris larger than one and ½” inches (1.5”) in diameter will appear on the surface. The finished surface will be on an even plane with all sidewalks, curbs, or borders. Slopes will not be greater than four horizontal to one vertical (4:1) for all seeded or sodded areas without approval from the Parks & Recreation Director or designee. All property pins will be set and clearly marked before construction begins and will be preserved until final acceptance by the Town. On sloping ground, the final harrowing or disking operation will be on the general contour.

1023.02 Seedbed Preparation Process for Open Space and Native Seeded Areas

1023.03 Annual Weed Removal Procedure

Open space areas, which are covered by weedy plant communities dominated by such species as: Kochia, Cheatgrass, Russian thistle, Blue mustard, annual ryegrass, diffuse knapweed, Scotch, Bull or Musk thistles, Puncture vine, etc. must be prepared for seeding by moldboard plowing in order to turn over and bury the weed seeds well below the seed bed surface prior to seeding. These areas should first be rotary mowed, moldboard plowed, spread with required organic amendments (below), and then disked to prepare the seedbed for planting. This treatment does not substitute for the requirement to pre-treat weedy areas with broad spectrum herbicides (Section 1021, above).

1023.04 Organic Matter for Native Seeded Areas

Native seeded areas in open space will receive the specified Class 1 organic material at the rate of three (3) cubic yards per one thousand (1000) square feet. Native areas shall be amended with Forte Biosol after seeding, but prior to hydromulching at a minimum rate of eight hundred (800) pounds per acre. Organic materials shall be applied when the surface is within two (2) percent of final grade. No organic material containing manure shall be stockpiled on the site for more than eight (8) hours before it is incorporated into the soil. After tilling, the areas to be seeded or sodded will be raked, graded, and rolled to the desired finished grades according to the grading plan within a tolerance of one-tenth (0.1) foot, with gently sloping surfaces to adequately drain all surface water run-off. The finished surface will be even and uniform, and no dirt clumps or other debris larger than 1 and ½ inches (1 ½”) diameter will appear on the surface. The finished surface will be on an even plane with all sidewalks, curbs, or borders. Slopes will not be greater than four horizontal to one vertical (4:1) for all seeded or sodded areas. All property pins will be set and clearly marked before construction begins and will be preserved until final acceptance by the Town. On sloping ground, the final harrowing or disking operation will be on the general contour.

1024.00 Inspections

When the Contractor is prepared for one (1) of the required inspections, he will give the Town forty-eight (48) hours' notice to visit the site and perform the inspection. This does not preclude the right of the Town to make informal inspections at any time. The Contractor must notify the Town for inspections of materials and soil preparation.

Written confirmation shall be provided to the Parks & Recreation Director or designee that all punch list items are fully completed prior to any punch walk being scheduled.

1024.01 Materials Inspection

The Town will inspect all compost, manure, organic materials, seed and seed tags, mulch, and fertilizer upon delivery to the site. Any unsatisfactory materials will be removed and replaced with materials conforming to these STANDARDS AND SPECIFICATIONS. Weight tickets, sod delivery tickets and/or grass seed analysis labels for all materials must be submitted to the Town. The Town's Project Manager/Inspector will confirm receipt of the order before materials are spread.

1024.02 Soil Preparation Inspection

The Town will inspect the soil preparation for conformance to the accepted plans and these STANDARDS AND SPECIFICATIONS during or immediately following the completion of each segment of the project. Any workmanship deemed by the Town to be faulty or not in accordance with the accepted plans and these STANDARDS AND SPECIFICATIONS will be corrected at this time by the Contractor. The following is a list of the required inspections in their order:

Prior to the commencement of any landscape or irrigation, Contractor must certify through a field survey that the grade is within plus or minus 0.1 feet of final grading elevation, at the following times during the construction process:

- During or after first cultivation
- After application of specified organic materials
- During or after second cultivation
- After final grade is completed.

1030.00 SEEDING SPECIFICATIONS

1031.00 General

The Contractor will provide all labor, equipment and materials necessary to furnish and install seed as required by the accepted plans and these STANDARDS AND SPECIFICATIONS.

1032.00 Materials

1032.01 Topsoil

Topsoil shall have an acidic reaction of 6.0 to 7.8 pH and shall not include any minerals or elements detrimental to plant growth. Soluble salts measured in saturation extract shall be 5 mmhos/cm or less.

Topsoil preparation will be as described in Section 1020.00, Topsoil Preparation, of these STANDARDS AND SPECIFICATIONS.

1032.02 Booster Fertilizer

All fertilizer requirements will meet the requirements of Section 1020.00, Topsoil Preparation, of these STANDARDS AND SPECIFICATIONS.

In conventional landscape and park areas a booster fertilizer with the chemical analysis of having a fertilizer with a ratio of approximately 5-15-1, with a minimum acceptable nitrogen level of 15%, and minimum acceptable Phosphorus level of 45%, with four (4) percent iron and eight (8) percent sulfur applied on the prepared soil at the rate of five (5) pounds per one thousand (1,000) square feet immediately prior to seeding.

Native seeded areas shall receive an application of 800 pounds per acre of Forte Biosol following seeding and before mulching.

1032.03 Bluegrass, Fine Fescue, Tall Fescue and Rhyzomatous Tall Fescue Seed

Seed will be furnished in sealed, unopened, standard containers and labeled in accordance with the USDA Rules and Regulations and the Federal Seed Act. Seed will be fresh, clean, pure live seed equal in quality to the standards for "Certified Seed". It will be capable of passing the USDA test for germination of eighty-five (85) percent and for purity of ninety (90) percent. Seed will be free of Poa annua and all noxious or objectionable weed and shall have a maximum weed crop of one-tenth (0.1) percent. Seed shall have been prepared for seeding during the year of installation and shall have been stored away from high heat (over 100 degrees F). The Town at the Contractor's expense may require tests of seed verification.

For turf areas to be maintained by the Town, all seed varieties used shall be tested within the most recent National Turfgrass Evaluation Program (NTEP) list of varieties, preferably tested in the intermountain west at either Logan UT, Sheridan WY, or other approved testing site for regional adaptability and approved by the Parks & Recreation Director or designee.

1032.04 Native Seed

Seed shall have been prepared for seeding during the year of installation and shall have been stored away from high heat (over 100 degrees F). Seed will be furnished in sealed, unopened, standard

containers and labeled in accordance with the USDA Rules and Regulations and the Federal Seed Act. Seed will be fresh, clean, pure live seed equal in quality to the standards for "Certified Seed". Seed tags must be supplied to the Parks & Recreation Director or designee for all seed mixtures, showing overall quantities and species. The Town at the Contractor's expense may require tests of seed verification.

1032.05 Top-dressing/Mulch

Hydro-mulch: Hydro-mulch shall be a wood cellulose fiber type and shall be applied at the minimum rate of two thousand five hundred (2,500) pounds per acre with a minimum rate of one hundred and fifty (150) pounds per acre tackifier and shall be applied immediately after seed application.

Straw: Straw consisting of 75% straws longer than 10 inches may be used on native seeding. It shall be applied evenly over the seeded surface at the minimum rate of two tons per acre and partially embedded into the soil using a crimper or similar implement. Due to the potential for wind-blown straw, hydromulch shall be required in native seeded areas close to occupied or neighboring buildings.

1033.00 Seeding Process**1033.01 Bluegrass, Fine Fescue, Tall Fescue and Rhyzomatous Tall Fescue Seeding****1033.01.01 Seeding dates**

All seeding will be done between March 15 and September 15 unless otherwise authorized in writing the Parks & Recreation Director or designee. No seeding shall be done when the soil is frozen, snow covered or excessively wet.

1033.01.02 Drill Seeding

Whenever possible, the seed will be applied using a drill seeder to drill the seed into a properly prepared seedbed. The seeder will be equipped with a satisfactory feeding mechanism, an agitator, double disc furrow openers, depth bands and packer wheels. Seed will be sown to a depth of one-quarter (1/4) inch into a properly prepared seedbed. Seed drilling will be done in two (2) separate applications crossing the area at right angles to one another to guarantee proper coverage. On sloping land, the final seeding operation will follow the general contour. All seeded areas will be top-dressed with hydro-mulch after the seeding is completed.

1033.01.03 Broadcast Seeding

In areas where the drill method of seeding cannot be used, a broadcast method may be substituted. If the broadcast method is used, the seeding rate must be doubled, and the area must be dragged after seeding followed by a suitable top dressing.

1033.02 Native Seeding

1033.02.01 Seeding dates

Dormant native seeding with standard mixtures of cool season and warm season grasses (Tables 1-7) must occur between October 30th and April 30th. In order to extend the seeding window and minimize erosion on projects, seeding of warm-season grasses will be allowed between April 1st and June 15th without supplemental irrigation, and through July 31st if adequate supplemental irrigation is present, as determined by Parks & Recreation Director or designee. Mixtures containing cool-season grasses only will be allowed between August 1st and October 30th. Dormant seeding shall still be required between October 30th and April 30th at prevailing rates to provide a full mixture of both cool and warm season grasses. Permission for exceptions to this seeding time must be obtained prior to seeding from the Parks & Recreation Director or designee. No seeding shall be done when the soil is frozen, snow covered or excessively wet.

1033.02.02 Drill seeding

Native seed shall be applied using a native grass drill seeder equipped with a seed box agitator and depth bands. Seed will be sown to a depth of one-quarter ($\frac{1}{4}$) to one-half ($\frac{1}{2}$) inch into a properly prepared seedbed. On sloping land, the seed shall be applied following the general contour.

1033.02.03 Broadcast seeding

In areas where drill seeding is not possible such as corners, near fences, along walkways, or around posts or boxes associated with electric, gas, irrigation installations or other similar situations, broadcast seeding may be substituted. No hydro seeding shall be permitted, except in wetland seeding areas. When using the broadcast method, the seeding area must be decompacted and harrowed after seeding, followed by mulching.

1033.02.04 Mulch application

Seeded areas will be mulched with twenty-five hundred (2,500) pounds per acre hydromulch immediately following seeding. Hydromulch must include one hundred and fifty (150) pounds per acre organic tackifier. At this rate soil coverage is 100%. Any thin areas in the mulch, where soil is visible, will be cause for a request to reapply mulch until the coverage is satisfactory, at the Contractor's expense. If weather conditions deteriorate, Contractor will delay work until conditions improve. Mulch must be applied in a separate operation on the same day as seeding.

No hay will be permitted on the construction site for any purpose.

1033.02.05 Cleanup

Remove all hydromulch from all plant materials, fences, concrete and other areas except for seed bed. Overly dense applications of straw mulch, or windrows of loose straw mulch which may smother seedling grasses, must be collected and removed. Straw mulch blown offsite during the construction and warranty period onto any adjacent area must be collected and removed by the landscape Contractor responsible for the project.

1033.03 Erosion Control Blankets

All erosion control blankets shall conform to the Erosion Control Technology Council's "Standard Specifications for Rolled Erosion Control Products" (see following chart, reprinted courtesy of Erosion Control Technology Council). Generally, Town-owned, Town-maintained projects will require a 'short term' blanket, with up to 12 month functional longevity. Other duration products and longevities may be required for specific projects. All erosion control blanket samples must be approved by the Parks & Recreation Director or designee prior to their use.

Table 1. ECTC Standard Specification For Temporary Rolled Erosion Control Products

Type		Product Description	Material Composition	Slope Applications*	Channel Applications*	Minimum Tensile Strength ¹
ULTRA SHORT-TERM - Typical 3 month functional longevity						
1.A	Mulch Control Nets	A photodegradable synthetic mesh or woven biodegradable natural fiber netting.		Maximum Gradient 5:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 0.25 lbf/ft ² (12 Pa)	5 lbf/ft (0.073 kN/m)
1.B	Netless Rolled Erosion Control Blankets	Natural and/or polymer fibers mechanically interlocked and/or chemically adhered together to form a RECP.		Maximum Gradient 4:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 0.5 lbf/ft ² (24 Pa)	5 lbf/ft (0.073 kN/m)
1.C	Single-net Erosion Control Blankets & Open Weave Textiles	Processed degradable natural and/or polymer fibers mechanically bound together by a single rapidly degrading, synthetic or natural fiber netting or an open weave textile of processed rapidly degrading natural or polymer yarns or twines woven into a continuous matrix.		Maximum Gradient 3:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 1.5 lbf/ft ² (72 Pa)	50 lbf/ft (0.73 kN/m)
1.D	Double-net Erosion Control Blankets	Processed degradable natural and/or polymer fibers mechanically bound together between two rapidly degrading, synthetic or natural fiber nettings.		Maximum Gradient 2:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 1.75 lbf/ft ² (84 Pa)	75 lbf/ft (1.09 kN/m)
SHORT-TERM - Typical 12 month functional longevity						
Type		Product Description	Material Composition	Slope Applications*	Channel Applications*	Minimum Tensile Strength ¹
2.A	Mulch Control Nets	A photodegradable synthetic mesh or woven biodegradable natural fiber netting.		Maximum Gradient 5:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 0.25 lbf/ft ² (12 Pa)	5 lbf/ft (0.073 kN/m)
2.B	Netless Rolled Erosion Control Blankets	Natural and/or polymer fibers mechanically interlocked and/or chemically adhered together to form a RECP.		Maximum Gradient 4:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 0.5 lbf/ft ² (24 Pa)	5 lbf/ft (0.073 kN/m)
2.C	Single-net Erosion Control Blankets & Open Weave Textiles	An erosion control blanket composed of processed degradable natural or polymer fibers mechanically bound together by a single degradable synthetic or natural fiber netting to form a continuous matrix or an open weave textile composed of processed degradable natural or polymer yarns or twines woven into a continuous matrix.		Maximum Gradient 3:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 1.5 lbf/ft ² (72 Pa)	50 lbf/ft (0.73 kN/m)
2.D	Double-net Erosion Control Blankets	Processed degradable natural and/or polymer fibers mechanically bound together between two degradable, synthetic or natural fiber nettings.		Maximum Gradient 2:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 1.75 lbf/ft ² (84 Pa)	75 lbf/ft (1.09 kN/m)
EXTENDED-TERM - Typical 24 month functional longevity						
Type		Product Description	Material Composition	Slope Applications*	Channel Applications*	Minimum Tensile Strength ¹
3.A	Mulch Control Nets	A slow degrading synthetic mesh or woven natural fiber netting.		Maximum Gradient 5:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 0.25 lbf/ft ² (12 Pa)	25 lbf/ft (0.36 kN/m)
3.B	Erosion Control Blankets & Open Weave Textiles	An erosion control blanket composed of processed slow degrading natural or polymer fibers mechanically bound together between two slow degrading synthetic or natural fiber nettings to form a continuous matrix or an open weave textile composed of processed slow degrading natural or polymer yarns or twines woven into a continuous matrix.		Maximum Gradient 1.5:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 2.00 lbf/ft ² (96 Pa)	100 lbf/ft (1.45 kN/m)
LONG-TERM - Typical 36 month functional longevity						
Type		Product Description	Material Composition	Slope Applications*	Channel Applications*	Minimum Tensile Strength ¹
4	Erosion Control Blankets & Open Weave Textiles	An erosion control blanket composed of processed slow degrading natural or polymer fibers mechanically bound together between two slow degrading synthetic or natural fiber nettings to form a continuous matrix or an open weave textile composed of processed slow degrading natural or polymer yarns or twines woven into a continuous matrix.		Maximum Gradient 1:1 (H:V)	Permissible Shear Stress ^{3, 4, 6} = 2.25 lbf/ft ² (108 Pa)	125 lbf/ft (1.82 kN/m)

Notes:
 * "C" factor and shear stress for Types 1.A, 2.A, and 3.A mulch control nettings must be obtained with netting used in conjunction with pre-applied mulch material.
¹ Minimum Average Roll Values when tested in the machine direction using ECTC Modified ASTM D 5035.
² "C" Factor calculated as ratio of soil loss from RECP protected slope (tested at specified or greater gradient, h:v) to ratio of soil loss from unprotected (control) plot in large-scale testing. These performance test values should be supported by periodic bench scale testing under similar test conditions using ECTC Test Method # 2.
³ Minimum shear stress RECP (unvegetated) can sustain without physical damage or excess erosion (> 12.7 mm/0.5 in) soil loss] during a 30-minute flow event in large-scale testing. These performance test values should be supported by periodic bench scale testing under similar test conditions and failure criteria using ECTC Test Method # 3.
⁴ The permissible shear stress levels established for each performance category are based on historical experience with products characterized by Manning's roughness coefficients in the range of 0.01 - 0.05.
⁵ Acceptable large-scale test methods may include ASTM D6459 or other independent testing deemed acceptable by the engineer.
⁶ Acceptable large-scale testing protocol may include ASTM D6460 or other independent testing deemed acceptable by the engineer.

1034.01 Bluegrass Seed Rate

All bluegrass seed will be drilled at the rate of three and one-half (3.5) pounds pure live seed (PLS) per 1,000 square feet, or one hundred-fifty (150) pounds pure live seed (PLS) per acre. If broadcast seeding is required, rates should be doubled. The seed mixture will consist of a blend of at least four (4) varieties of bluegrass. The specific varieties and percentages of each variety will be determined by the Parks & Recreation Director or designee.

1034.02 Tall Fescue and Rhizomatous Tall Fescue Seeding Rate

Seed shall be applied at the rate of five (5) pounds of pure live seed (PLS) per 1,000 square feet (220 pounds PLS/acre), consisting of a minimum of three (3) varieties of Tall Fescue and/or Rhizomatous Tall Fescue seed using a drill seeder. If broadcast seeding is required, rates should be doubled. Specific varieties and percentages of each variety shall be determined by the Parks & Recreation Director or designee.

1034.03 Fine Fescue Seeding Rate

Fine fescue seed shall be applied at the rate of five (5) pounds of pure live seed (PLS) per 1,000 square feet (220 pounds PLS/acre), consisting of a minimum of three (3) varieties of Fine Fescue seed using a drill seeder. If broadcast seeding is required, seeding rates should be doubled. Specific varieties and percentages of each variety shall be determined by the Parks & Recreation Director or designee.

1034.04 Native Seed Rates and Mixtures

The following seed mixtures may be used for native seeded areas. Substitution of other mixtures may be made only with prior approval by the Parks & Recreation Director or designee.

Table 1. Mixed Grass Prairie Native Seed Mixture: For use in open space native seeding at least 15 feet away from road and trail edges. This mixture is for general usage, is dominated by short to mid-sized native prairie grasses (6-18 inches in height), but includes a few taller species (up to 36 inches). Best for use in larger open space areas. Be sure to over seed any swales or moist areas within this seeding type with the Moist Swale Seed Mixture (Table 3). While seeding is preferred beginning in late winter (After February 1st), this mixture may be used between October 30th and April 30th only without supplemental irrigation. If adequate supplemental irrigation is in place, this mixture may be seeded through June 15th.

COMMON NAME	SCIENTIFIC NAME	VARIETY	OZ/ACRE	PLS LBS/ACRE
Buffalo grass	<i>Buchloe dactyloides</i>	Native, Bison or Texoka		3
Sideoats grama	<i>Bouteloua curtipendula</i>	Butte, Niner or El Reno		5
Prairie sandreed	<i>Calamovilfa longifolia</i>	Goshen or Bowman		1
Blue grama	<i>Chondrosium gracile</i>	Lovington, Alma, Native or Hachita		3
Western wheatgrass	<i>Pascopyrum smithii</i>	Arriba, or Rosana		5
Little bluestem	<i>Schizachryium scoparium</i>	Pastura, Cimarron, Aldous Camper		4
Alkali sacaton	<i>Sporobolus airoides</i>	Common		1
Sand dropseed	<i>Sporobolus cryptandrus</i>	Common		1
Switchgrass	<i>Panicum virgatum</i>	Blackwell		5
SEEDING RATE POUNDS PLS/ACRE				28
Optional Addition of Native Wildflowers				
Fringed sage	<i>Artemisia frigida</i>	Common	1	
Purple prairie clover	<i>Dalea purpurea</i>	Common	6	
Blanketflower	<i>Gaillardia aristata</i>	Common	6	
Gayfeather	<i>Liatris punctata</i>	Common	4	
Tansy aster	<i>Machaeranthera tanacetifolia</i>	Common	3	
Prairie coneflower	<i>Ratibida columnifera</i>	Common	3	
OUNCES			23	1.4375
SEEDING RATE POUNDS PLS/ACRE WITH NATIVE WILDFLOWERS OPTION				29.4375

Table 2. Shortgrass Prairie Native Seed Mixture. For use in open space native seeding less than 25 feet from road and trail edges, or within the top of slope above roadway/trail and inside the toe of slope below roadway/trail if sloped areas are present adjacent to roadway or trail. This mixture is for specific usage near trails or where shorter grasses are desired (such as smaller park sites). It is dominated by short to mid-sized native prairie grasses (6-18 inches in height). Best for use along roads and trails and in smaller native seeded park areas. Be sure to over seed any swales or moist areas within this seeding type with the moist swale seed mixture (Table 3). While seeding is preferred beginning in late winter (after February 1st) this mixture may be used between October 30th and April 30th only without supplemental irrigation. If adequate supplemental irrigation is in place, this mixture may be seeded through June 15th.

COMMON NAME	SCIENTIFIC NAME	VARIETY	OZ/ACRE	PLS LBS/ACRE
Buffalograss	<i>Buchloe dactyloides</i>	Native, Bison or Texoka		14
Blue grama	<i>Chondrosum gracile</i>	Lovington Alma,Native, or Hachita		12
Sand dropseed	<i>Sporobolus cryptandrus</i>	Common		4
SEEDING RATE POUNDS PLS/ACRE				30
<u>Optional Addition of Native Wildflowers</u>				
Fringed sage	<i>Artemisia frigida</i>	Common	1	
Purple prairie clover	<i>Dalea purpurea</i>	Common	4	
Gayfeather	<i>Liatris punctata</i>	Common	4	
Tansy aster	<i>Machaeranthera tanacetifolia</i>	Common	3	
OUNCES			12	0.75
SEEDING RATE POUNDS PLS/ACRE WITH NATIVE WILDFLOWERS OPTION				30.75

Table 3. Moist Swale Seed Mixture. This mixture is intended to be seeded over the top of either Table 1 or Table 2 seed mixtures in locations which may be moist at least some of the year (such as pond edges, small or larger swales or ditches within the open space areas or along roads, in detention or retention basins, or along the inner banks of irrigation ditches. Be sure to seed one of the other seed mixtures first and then add this mixture to provide adequate species adapted to moist conditions. This mixture may be used between October 30th and June 15th without supplemental irrigation, and from June 16th through July 31st if adequate supplemental irrigation is present and acceptable to the Parks & Recreation Director or designee.

COMMON NAME	SCIENTIFIC NAME	VARIETY	PLS LBS/ACR
Woolly sedge	<i>Carex lanuginosa</i>	Native	0.5
Nebraska sedge	<i>Carex nebrascensis</i>	Native	0.1
Blue grama	<i>Chondrosum gracile</i>	Lovington, Alma,Native or Hachita	1.5
Buffalograss	<i>Buchloe dactyloides</i>	Native, Bison or Texoka	0.5
Inland saltgrass	<i>Distichlis stricta</i>	Native	0.5
Baltic rush	<i>Juncus balticus</i>	Native	0.1
Prairie cordgrass	<i>Spartina pectinata</i>	Native	1
Alkali sacaton	<i>Sporobolus airoides</i>	Native	3
Switchgrass	<i>Panicum virgatum</i>	Blackwell	3
Western wheatgrass	<i>Pascopyrum smithii</i>	Arriba or Rosana	5
SEEDING RATE POUNDS PLS/ACRE			15.2
Optional Addition of Native Wildflowers			
Aster	<i>Aster laevis</i>		0.05
Yarrow	<i>Achillea millefolium</i>	Western	0.05
Prairie coneflower	<i>Ratibida columnifera</i>		0.05
SEEDING RATE POUNDS PLS/ACRE WITH NATIVE WILDFLOWER OPTION			15.35

Table 4. Roadside Native Seed Mixture. This mixture is intended for use for seeding of Public Works roadside re-vegetation projects. It is an adaptable mix of short to mid-sized native and introduced warm and cool season grasses. Use for Public Works roadside and right-of-way seeding projects only. This mixture may be used between October 30th and April 30th only.

COMMON NAME	SCIENTIFIC NAME	VARIETY	PLS LBS/ACR E
Western wheatgrass	<i>Pascopyrum smithii</i>	Arriba or Rosana	7.0
Crested wheatgrass	<i>Agropyron cristatum</i>	Ephriam	4.0
Streambank wheatgrass	<i>Elymus lanceolatus</i>	Sodar	4.0
Sideoats grama	<i>Bouteloua gracilis</i>	Butte, Niner or El Reno	2.0
Blue grama	<i>Bouteloua gracilis</i>	Lovington, Alma, Native or Hachita	5.0
Buffalograss	<i>Buchloe dactyloides</i>	Native, Bison or Texoka	3.0
Sand dropseed	<i>Sporobolus cryptandrus</i>	Common	1.0
Prairie Junegrass	<i>Loeleria macrantha</i>	Common	3.0
Hard Fescue	<i>Festuca brevipila</i>	'Durar'	3.0
SEEDING RATE POUNDS PLS/ACRE			32.0

Table 5. Warm Season Mixed Grass Prairie Native Seed Mixture For use in open space native seeding at least 25 feet away from road and trail edges, or beyond the top of slope above roadway/trail and inside the toe of slope below roadway/trail if sloped areas are present adjacent to roadway or trail. This mixture is for general usage, is dominated by short to mid-sized native prairie grasses (6-18 inches in height), but includes a few taller species (up to 36 inches). Best used in larger open space areas. This mixture is to be used between April 1st and June 15th ONLY, unless sufficient supplemental irrigation is present. Irrigation must be approved by Parks & Recreation Director or designee. If present, mixture can be seeded between June 16th and July 31st.

COMMON NAME	SCIENTIFIC NAME	VARIETY	PLS POUNDS/ACRE
Side Oats Grama	Bouteloua curtipendula	Butte, Niner or El Reno	4
Blue Grama	Bouteloua gracilis	Lovington, Alma,Native or Hachita	4
Buffalograss	Buchloe dactyloides	Native, Bison or Texoka	4
Switchgrass	Panicum virgatum	Blackwell	6
Little Bluestem	Schizachyrium scoparium	Pastura, Aldous, Cimarron or Camper	6
Alkali Sacaton	Sporobolus airoides	Sabado	6
Sand bluestem	Andropogon hallii	Garden	6
Sand Lovegrass	Eragrostis trichodes	Nebraska 27	3
Sand Dropseed	Sporobolus cryptandrus	Common	3
SEEDING RATE POUNDS PLS/ACRE			30.00

Table 6. Warm Season Shortgrass Prairie and Roadside Native Seed Mixture: This mixture is an adaptable mix of short to mid-size native warm season grasses with specific usage near trails or where shorter grasses are desired (such as smaller park sites). It is dominated by short to mid-sized native prairie grasses (6-18 inches in height). Use for areas within 25 feet from road and trail edges, or within the top of slope above roadway/trail and inside the toe of slope below roadway/trail if sloped areas are present adjacent to roadway or trail, as well as for Public Works roadside and right-of-way seeding projects between the months of April 1st and June 15th ONLY, unless sufficient supplemental irrigation is present. If sufficient irrigation is present as determined by the Parks & Recreation Director or designee, this mixture can be seeded between June 16th and July 31st.

COMMON NAME	SCIENTIFIC NAME	VARIETY	PLS POUNDS/ACRE
Side Oats Grama	Bouteloua curtipendula	Butte, Niner or El Reno	8
Blue Grama	Bouteloua gracilis	Lovington, Alma, Native or Hachita	10
Buffalograss	Buchloe dactyloides	Native, Bison or Texoka	12
SEEDING RATE POUNDS PLS/ACRE			30.00

Table 7. Cool Season Grass Native Seed Mixture: This mixture shall be used for Mixed Grass Prairie, Moist Swale and Roadside locations ONLY between the dates of August 1st and October 30th. Areas adjacent to trails shall be seeded with the standard Shortgrass Prairie Native Seed Mixture between the months of October 30th and April 30th ONLY.

COMMON NAME	SCIENTIFIC NAME	VARIETY	PLS POUNDS/ACRE
Western Wheatgrass	Pascopyrum smithii	Arriba or Rosana	12
Crested Wheatgrass	Agropyron cristatum	Ephriam	9
Streambank Wheatgrass	Elymus lanceolatus	Sodar	9
SEEDING RATE POUNDS PLS/ACRE			30.00

1034.05 Additional Seed Varieties

Additional native and/or non-native seed varieties may be considered on a case-by-case basis. All varieties, mixtures, seed rates and dates of application not within Tables 1-7 above MUST be approved by the Parks & Recreation Director or designee prior to seeding.

1035.00 Maintenance Procedures

1035.01 Maintenance Procedures for Bluegrass, Fine Fescue, Tall Fescue and/or Rhizomatous Tall Fescue Grasses.

1035.01.01 Warranty

The Contractor will warranty the life and good health of the seed installed until the entire project has been accepted by Board of Trustees. Any areas deemed by the Town to be thin, weak, or dead will be reseeded according to these STANDARDS AND SPECIFICATIONS and germinated prior to the beginning of the two year warranty period.

1035.01.02 Signage

The Contractor will erect suitable signs at strategic points notifying the public to keep off the seeded areas until the lawn is well established. Any traffic damage that may occur prior to final acceptance of the work will be repaired and reseeded at the Contractor's expense.

1035.01.03 Mowing

During the maintenance period, after a suitable stand of grass has been established, the Contractor will begin mowing all lawn areas on a routine basis using a mowing height of three inches (3") for bluegrass and fine fescue, and four inches (4") for tall fescue or rhizomatous tall fescue. Frequency of mowing will be determined by the growth rate of the grass but at no time should the clippings exceed 1/3 of the total grass blade height.

Only turf-type mowers will be used for this operation.

1035.01.04 Additional Fertilizing

At the time of the first mowing, the Contractor will apply a commercial fertilizer with a ratio of 4-1-2 NPK, such as Nitrogen-20, Phosphorous-5, Potash-10, plus two percent (2%) iron at the rate of five (5) pounds per one thousand (1,000) square feet. Care should be taken to prevent burning. Any areas disturbed or damaged by the Contractor during fertilizing operations will be repaired in accordance with these STANDARDS AND SPECIFICATIONS at the Contractor's expense.

1035.01.05 Watering

The Contractor will be responsible for watering the newly seeded area(s) a minimum of two (2) times per day (mid-morning and late afternoon) and for keeping the areas moist until the lawn is established. For Town owned and maintained native areas, the Contractor must coordinate with Town staff to adjust watering times once seed establishment has begun. The Contractor will be

responsible for obtaining a temporary meter from the Public Works Department, and for all water usage until such time as the project is accepted by the Town.

1035.02 Maintenance Procedures for Native and Open Space Areas

1035.02.01 Maintenance period

Contractor maintenance period minimum shall be the two (2) year warranty period or until Town acceptance of the site (Final Acceptance). Extended warranty period may be required as determined by the Town’s representative. Seeded areas must be maintained in a weed free manner. Weed infestations must be mowed, or spot treated with approved herbicides starting during construction phase and during two year post installation warranty period. It is recommended maintenance activities be reported regularly to the Parks & Recreation Director or designee, to assure a complete record of activities is on file in support of the Final Acceptance Inspection (at the closure of the two year warranty period).

1035.02.02 Signage

The contractor is responsible for providing and installing barriers as required to protect seeded areas from pedestrian and vehicular damage. Provide signage and barricades as needed.

1035.02.03 Litter removal

All litter or trash from construction sites or other sources which may blow onto Open Space must be collected and removed from the area weekly, in order to prevent smothering of establishing vegetation. Placement of an orange construction fence between construction areas and Open Space may facilitate litter collection.

1035.02.04 Access

Vehicular traffic is not permitted on Open Space areas, except for approved maintenance vehicles on established trails and sidewalks. Mowing, re-seeding, and spray equipment are allowed off trails, but must avoid all access immediately following precipitation or irrigation events which may lead to rutting. All damage to irrigation installations must be repaired at the Contractor’s expense, according to the original specifications.

1035.02.05 Weed Control Maintenance

Annual weeds must be mowed when they exceed 12 inches in height. Rotary mowers must be used for mowing operations. Dense accumulations of mowed weeds must be collected to prevent smothering of desirable vegetation. At a minimum, this will require mowing at least twice (late May and late August) during normal years; and could require mowing more frequently in wet years or if the site is heavily irrigated.

State listed noxious weeds or other problematic weedy species of concern (some of which are listed below) shall be spot treated with approved herbicides with approved application methods at

approved times for effective control, at least twice each year. For acceptable results, most of these species should be sprayed during late May/early June and again in late August/September. Other non-native weedy species of concern in the Erie area include, but may not be limited to: Common (or great) mullein (*Verbascum thapsus*) Thistles (including Bull, Canada, Scotch and Musk Thistles), Purple Loosestrife (*Lythrum salicaria*), Field Bindweed (*Convolvulus arvensis*), Blue Mustard (*Chorispora tenella*), Diffuse Knapweed (*Centaurea diffusa*), Kochia (*scoparia*) and Curly dock (*Rumex crispus*). For a full listing of problematic weeds which must be eradicated or controlled, refer to the most recent edition of ‘Noxious Weeds of Colorado’, using Lists A, B, and C.

Herbicide selection, concentration, and timing of application must be approved by the Town’s representative prior to application. Broadcast application of herbicides with boom sprayers will not be allowed unless approved by the Town’s representative in writing. Spot treatment of weeds with spray guns on 4 wheelers or back packs is acceptable. Permission must be obtained from the Parks & Recreation Director or designee for exception to this regulation.

1035.02.06 Irrigation

The Contractor will be responsible for temporary irrigation on all native seed areas and for water usage until such time as the seeding is established and accepted. The Contractor will be responsible for initial watering the native seeded area and for keeping the area adequately moist until seed is established. Over watering can be detrimental to the success of native seeding. Failed seedling establishment due to over or under watering must be reseeded and re-mulched. Assistance in preparation of site specific irrigation schedule for native seeded areas is available from the Parks Division upon request.

General recommended watering schedule for native seeded areas. Watering is generally unnecessary until May or June following winter or early spring seeding.

WEEKS AFTER SEEDING	FREQUENCY	DURATION	TIMING
first month, or until initial germination (May or June)	2 times per day	15 minutes or until soil is moist to 1 inch depth	10 AM, 10 PM (to provide extended period of soil moisture at night)
4-6 weeks	2 times per week	20 minutes or until soil is moist to 2 inch depth	10 PM (after evening winds subside)
7-10 weeks	1 time week	30 minutes or until soil is moist to 3 inch depth.	10 PM (after evening winds subside)
11 weeks to late September	every other week	30 minutes or until soil is moist to 3 inch depth	10 PM (after evening winds subside)

1035.02.07 Standard of acceptable establishment for native seeding:

Warrant seeded areas for consistency and completion of coverage. The standard of acceptable establishment shall be at least six (6) desirable seeded plant seedlings per square foot. All bare areas over 10 square feet in size shall be re-seeded and re-mulched.

TWO YEAR WARRANTY PERIOD SEEDING MAINTENANCE REQUIREMENTS

ACTIVITIES	SEASONAL FREQUENCY	APPROXIMATE DATES	COMMENTS
Installation protection	Keep initial installation repaired	As required	Place fencing and signage to prevent unauthorized vehicle access and disturbance to seeded and planted areas. Maintain fencing and signage on preserved remnant areas and trees.
Collect wind drift of straw mulch	After initial installation and before germination	As required before germination	Incompletely crimped straw mulch may blow into dense drifts which can smother seeded areas. Check for these and remove excess straw prior to germination.
Litter collection	Collect litter to prevent smothering	As required	Collect construction or other litter which blows onto open space to prevent smothered vegetation and repairs. Placing an orange fence between construction site and the edge of open space may help concentrate litter off the vegetation and reduce clean up time.
Repair seeded or planted areas damaged by irrigation malfunction, tire ruts, erosion		As required	Construction damage to open space vegetation should be repaired immediately.
Annual weed control	Two or more times per growing season	Late May to early June and again in late August to early September	Annual weeds, including Annual ryegrass, Russian thistle, and Kochia should be mowed when they exceed 12 inches in height. Generally mowing is necessary at least twice a year for a couple years. More frequent mowing could be needed in wet years. Do not mow when the site is muddy to prevent ruts and repairs.
Noxious weed control	Two or more times per growing season	Late May to early June and again in late August to early September	Several species of noxious weeds occur in the Erie area: Canada thistle*, Musk thistle, Scotch thistle, Diffuse knapweed*, Blue mustard. All noxious species (if they occur on the development site) must be treated (*treat twice a year) with the proper concentration of effective chemicals, with the proper equipment, at the correct times in order to receive full credit for the warranty period. Consult a certified weed control specialist for best results.
Irrigation	See irrigation table in Standards and Specifications (Section 1035.02.06)	May through September of first year following winter to early spring seeding	Temporary irrigation during establishment is required for native seeding in Erie Open Space.
Reporting activities	Regularly	As completed	To assure full credit for proper warranty period activities, it is recommended that regular reports for all required two year warranty maintenance activities be filed with the Town of Erie Parks & Recreation Director or designee to provide a complete record for consultation during the Final Acceptance Inspection. (Regularly submitted reports help prove due diligence.)

1036.00 Inspections

Inspections shall be completed in accordance with Section 1024.00, Inspections, of these STANDARDS AND SPECIFICATIONS. The Contractor must notify the Town for inspections of seed certification and germination.

1036.01 Inspection of Seed Certifications

Seed certification tags shall be delivered to the Town to verify compliance with these STANDARDS AND SPECIFICATIONS.

1036.02 Germination Inspection

When germination is complete and plants are visible, the Contractor will notify the Town and request an initial germination inspection for approval in order to begin the guarantee period (warranty period, two year maintenance period). Any areas deemed by the Town to be thin, weak or dead will be replaced at this time. All washouts will be reseeded immediately after the germination inspection. No partial acceptance will be made.

1040.00 SODDING SPECIFICATIONS**1041.00 General**

The Contractor will provide all labor, equipment and materials necessary to furnish and install all sod as required by the accepted plans and these STANDARDS AND SPECIFICATIONS.

1042.00 Materials**1042.01 Topsoil**

Topsoil preparation will be as described in Section 1020.00, Topsoil Preparation, of these STANDARDS AND SPECIFICATIONS.

1042.02 Booster Fertilizer

All fertilizer will meet the requirements of Section 1020.00, Topsoil Preparation, of these STANDARDS AND SPECIFICATIONS. A booster fertilizer with a ratio of 4-2-1 NPK, with a sample chemical analysis of Nitrogen 20, Phosphorous 10, Potash 5 with three percent (3%) iron will be applied at a rate of five (5) pounds per one thousand (1,000) square feet immediately prior to sodding. For Buffalograss sod, the rate of fertilization shall be two (2) pounds per one thousand (1,000) square feet.

1042.03 Sod

The sod will consist of a blend of at least four (4) varieties of bluegrass, or a blend of at least three varieties of fine fescue or tall fescue/rhizomatous tall fescue. This blend is to be approved by the Parks & Recreation Director or designee prior to installation. Additionally, the use of Buffalograss sod is a viable alternative for low water xeriscape plantings. Varieties chosen shall be either 'Native', 'Bison' or 'Texoka', or a combination thereof.

Sod will be strongly rooted and free of noxious weeds, undesirable plants, roots, stones, and other foreign materials that will be detrimental or will hinder the proper development of the sod. The sod will be procured from areas where the soil is reasonably fertile and contains a high percentage of loamy topsoil. The sod will be cut from living, thickly matted turf. The sod will be mowed to a height not to exceed two inches (2") and thoroughly watered before the sod is cut. All sod will be cut to provide a minimum thickness of three-fourths inch (3/4") of soil adhering to the roots. The Contractor will furnish written proof of sod variety to the Town. Sod must be tested by the Colorado State University laboratory or a certified laboratory at the Contractor's expense if requested by the Town.

1043.00 Sodding Process**1043.01 Care and Handling**

Care will be exercised at all times to retain the native soil on the sod roots during transportation, handling and planting. Dumping sod from vehicles will not be permitted. The sod will be transported to the site within twenty-four (24) hours from the time it is cut, unless it can be stored to the satisfaction of the Town. During delivery and while in stacks, all sod will be kept moist and protected from exposure to the wind, sun and freezing. All damaged or dry sod will be rejected.

1043.02 Transporting Sod On-Site

Sod can be transported on or across the site on pallets by forklift. Damage to the sod bed by the vehicles will be kept to a minimum and will be re-graded before sodding of the area. Damage caused to paving, curbs, fence, plants or other objects during sodding, will be repaired or replaced by the Contractor at his expense as directed by the Town.

1043.03 Sodding

The sod bed will be lightly sprinkled just prior to laying the sod. Do not create muddy soil. All sod strips will be placed tightly against each other so no open joints are apparent. Joints between ends of strips will be staggered at least one foot (1') between adjacent rows. At the end of walks and drives, the sod will have the same finish grade as the abutting surfaces. At curbs the sod will have the same finish grade as the top of the curb. Sod placed on slopes equal to four horizontal to one vertical (4:1) will be staked with wire pins not less than six inches (6") long and spaced not more than thirty inches (30") apart. The pins shall be driven into the ground at an angle against the flow of the water

until the top of the stake is three inches (3") above the sod. Sod laying will begin at the bottom of the slope and progress upward with strips laid transverse to the slopes. Immediately after the sod has been laid, it should be tamped or rolled as needed with approved equipment to eliminate all air pockets and to provide a smooth, even surface. Immediately after rolling or tamping the sod, sufficient water will be applied to completely saturate the sod. The sod will be watered as often as required to prevent it from drying out. Settled sod areas will be pulled up, re-graded, relayed, and retamped.

1043.04 Sodding Inspections

When sodding operations are complete, the Contractor will notify the Town and request a sodding inspection. Any areas deemed by the Town to be thin, weak or dead will be replaced at this time. Sod must be installed a minimum of three weeks before Contractor calls the Town's project manager for a landscape or sod inspection. No partial acceptance will be made.

1044.00 Cleanup

Any remaining peat, soil, sand, rock, or similar material which has been brought onto the site by work operations or otherwise, will be removed, and all other remaining debris will be disposed of. All ground area disturbed as a result of the sodding operations will be renovated to its original condition or to the required new condition.

1045.00 Maintenance

The proper care and maintenance of the sodded areas will be the responsibility of the Contractor until the work has been completed and accepted by Parks & Recreation Director or designee. The maintenance operations will begin as soon as each portion of the area is sodded. Maintenance will consist of repair and replacement of eroded areas, watering, mowing (when the sod is established), weeding, fertilizing, and re-sodding as necessary to provide an even, consistent stand of grass. All replacement sodding deemed necessary by the Town will be done by the Contractor at his own expense.

1045.01 Mowing

During the maintenance period, after the sod is established, the Contractor will begin mowing all lawn areas on a routine basis using a mowing height of three inches (3") for bluegrass and Buffalograss sod, and four inches (4") for tall fescue/rhizomatous tall fescue sod. Frequency of mowing will be determined by the growth rate of the grass but at no time should the clippings exceed 1/3 the height of the grass blade

Only turf-type rotary or flail mowers will be used for this operation.

1045.02 Additional Fertilizing

Forty-five (45) days after sod is laid, an application of fertilizer with a ratio of 3-3-1 NPK, with a sample chemical analysis of Nitrogen-12, Phosphorous-12, Potash-4, with four percent (4%) iron and eight percent (8%) sulfur will be applied at the rate of six (6) pounds per one thousand (1,000) square feet. Buffalograss sod shall be fertilized at the rate of one (1) pound per thousand (1,000) square feet. When applied, the fertilizer must be dry and free flowing. All damage caused to the sod during fertilizer application will be repaired by the Contractor at his expense.

1045.03 Watering

The Contractor will be responsible for watering the sodded area(s) a minimum of two (2) times per day (mid-morning and late afternoon) and for keeping the areas moist until the sod is established. The Contractor will be responsible for water usage until such time as the project is accepted by the Board of Trustees.

1046.00 Landscape Inspections

Inspections shall be completed in accordance with Section 1024.00, Inspections, of these STANDARDS AND SPECIFICATIONS. The Contractor must notify the Town for inspection of sodding.

Approved construction drawings shall be on site daily and updated weekly with As-Built markups. Contractor will make As-Builts available for review and inspection to Town staff on site at all times on request. Record all changes which are made from the contract drawings. Landscape As-Builts will identify and record dimensioned locations for all components installed, and locate all dimensions from two permanent reference points. Record all required information on As-Built drawings. Do not use these prints for any other purpose.

1047.00 Landscape Warranty Period

The Contractor shall be responsible for the entire sprinkler system for a period of two (2) years from the date of acceptance of the entire project. If any trouble should develop within this time period due to faulty workmanship or material, the defect will be corrected in a timely fashion by the Contractor without expense to the Town. The Contractor will not be responsible for repair of the sprinkler system due to vandalism or due to erosion after the work has been accepted by the Town. Repair damages to the premises cause by defective items within a maximum of five (5) days of notification from the owner.

1050.00 SPRINKLER SYSTEMS**1051.00 General**

All irrigation design plans and specifications will be submitted to the Town in accordance with Section 160.00, Plans and Specifications, and Section 161.00, Construction Plan Requirements, and Section 1001.03 Irrigation Plans, of these STANDARDS AND SPECIFICATIONS. The Parks & Recreation Director or designee must review and accept the design plans prior to the commencement of any work. Three (3) sets of plans and specifications will be provided to the Town for this purpose. This review and acceptance process normally will take fourteen (14) calendar days from the time the plans and specifications are submitted to the Town.

The work will be performed in accordance with the best standards of practice relating to the various trades and under the continuous supervision of a competent foreman capable of interpreting drawings and specifications. The Contractor will notify the Town as soon as any discrepancies between plans and specifications are discovered. The work will include all labor, materials, equipment and appliances and obtaining of all permits required by governing codes to complete the work as indicated on the accepted plans and as herein specified. All work will comply with the building codes adopted by the Town of Erie. During progress of the work, the Contractor will keep the site as clean and free of rubbish as possible. All surplus and useless material resulting from this work will be removed from the site by the Contractor.

The Contractor will guarantee all material and workmanship for a minimum period of one (1) year from the date of acceptance of the work.

The Contractor will furnish the Town with:

- quick coupler key with hose swivel (1)
- drain key (1)
- turn-off key (1)
- control clock keys (2)
- valve box key
- head wrench (1 for each type of head)
- sprinkler heads (2 of each type)
- maintenance manuals for all components
- as built drawings
- controller charts at each field controller
- sample program

The location of all utilities will be completed by Contractor before any excavation work is started.

1051.01 Temporary Irrigation Systems

Native grasses are generally not to be irrigated with a permanent irrigation system, with the exception of arterial medians and rights of way which shall require permanent irrigation. Therefore,

temporary irrigation systems shall be allowed to water these areas during the grow-in/warranty period. Water for temporary systems must be metered, although this water is not calculated in the permanent water budget for the project. For Town owned and maintained systems, temporary irrigation shall be placed below ground.

At the conclusion of the warranty period (Final Acceptance), the system is to be disabled either prior to or past the main isolation valve, with a clear break between the permanent and temporary systems. The property owner shall remove any above ground temporary system at the conclusion of the warranty period.

1051.02 Coverage

For permanent irrigation systems, system must be designed to provide 100% head to head coverage with matched precipitation rates. For temporary irrigation systems, irrigation heads must reach at least 80% of the distance to the next head. Shrub and perennial beds are to be zoned separately. Heads shall not overspray walkways, pavements or other hard surfaces. Spray radius of heads will be limited to water only areas intended to be watered.

1051.03 Non-Potable Irrigation Systems

All Non-Potable irrigation systems must be clearly identified with standard signage as shown in the Town of Erie Standards and Specifications – Parks Details Section. One sign must be visible at each park-access point. Access points include where open space and trails adjoin a park, parking lots and curb cuts from streets, or any other point that may give access to parks from public thoroughway. A minimum of two signs must be installed at any location using non-potable irrigation even if only one access point exists

1052.00 Materials

1052.01 Water License and Tap Fee

The Contractor will purchase a water license and pay all applicable tap and meter fees prior to connecting into the Town’s water system. The size of the water tap will be determined and approved by the Town Building Official and/or the Town Engineer.

1052.02 Water Tap

All taps into Town water mains shall comply with the requirements of Section 643.00, Tapping the Main, of these STANDARDS AND SPECIFICATIONS.

1052.03 Water Service Line

The Contractor will be responsible for installing the water service line from the corporation stop valve to the meter pit. This will include a curb stop valve installed just behind the curb, between the

curb and the meter pit and all plumbing inside the meter pit. Reference Section 640.00, Water Service Line Construction, of these STANDARDS AND SPECIFICATIONS. Also refer to the Standard Drawings.

1052.04 Meter Pit

Refer to Section 632.124, Vaults, of these STANDARDS AND SPECIFICATIONS.

1052.05 Water Meter

The water meter will be provided by the Town. The fee is covered in Section 1052.01, Water License and Tap Fee, of these STANDARDS AND SPECIFICATIONS.

All water meters for irrigation systems will be turbo type and shall comply with all applicable portions of Section 642.00, Equipment and Materials, of these STANDARDS AND SPECIFICATIONS.

1052.06 Electrical Service

All service lines shall be run underground and in electrical PVC conduit. All wire shall be copper and shall be properly sized. If a booster pump is required, a sixty (60) amp (minimum) metered service shall be required. If the irrigation controller is the only electrical demand, an unmetered flat rate service can be installed. All electrical service lines shall have electrical warning tape in the trench six (6) inches above the conduit pipe. An electrical disconnect shall be mounted on the irrigation controller. Electrical box will be weather proof, vandal resistant. Box will be securely mounted and lockable. Electrical box will be grounded and installed according to local codes. All electrical buried within Parks and Open Space boundaries need to have a minimum of 36 inches of cover.

1052.07 Backflow Preventer

The backflow prevention device for water taps two (2) inches and smaller will be a Feb-Co 825-YA Series reduced pressure backflow preventer or approved equal.

Each backflow preventer shall be enclosed in a locked, stainless steel strong box with the following features:

Marine grade aluminum alloy construction

100% stainless steel hardware

Flush, mounted, locking mechanism for security

Full-release locking mechanism for service and repair access

Pre-punched viewing ports

Strongboxes shall be sized in accordance with manufacturer's recommendations, and must be approved by the Parks & Recreation Director.

For taps 3" and larger, the backflow prevention device will be a Febco 880 Series or approved equal. It will be sized in accordance with manufacturer's recommended velocities, but no velocities shall exceed the normal industrial practice of seven and a half (7.5) feet per second through the backflow device. The device will meet the requirements of ASSE Standard 1013; AWWA Standard Code C 506-78; and USC Foundation for Cross Connection Control and Hydraulic Research, latest edition.

Backflow preventer(s) shall be installed in accordance with the applicable sections of the UBC and in accordance with the Standard Drawings. It shall have either a brass union or a bolted flange connection on both the inlet and discharge side of the device.

All backflow prevention devices will be tested and certified before acceptance.

A Rain Bird 44QC quick coupler or approved equal will be installed adjacent, and downstream to backflow prevention device for winterization blow out connection.

1052.08 Booster Pump

The requirement for a booster pump will be determined by the Town water main static pressure and the design requirements of the irrigation system. When a booster pump is needed, it will be a Peerless-type P.E. or approved equal, with magnetic starter and heater and a time delay circuit. The heater, starter, and time delay will be approved by the Town prior to installation.

1052.09 Pump House

When a booster pump is needed, it will be enclosed in a concrete pump house similar to that manufactured by ADPC, Inc. The pump house will have an exposed aggregate finish; heavy duty hollow steel door and door jamb; and locking door knob with latch, matching the Town's current lock series as determined by Parks & Recreation Director or designee. The pump house will enclose all above ground plumbing, such as piping fittings, backflow preventer, and booster pump; all electrical equipment, such as breaker panels, switches, overhead light and outlets; and irrigation controllers. It shall have a minimum ceiling height of seven (7) feet.

All electrical equipment will be Square D, Cutler Hammer, G.E., or equivalent, and a waterproof type. All wire will be copper conductor and run in conduit.

1052.10 Controllers

The controller will be Hunter ACC or approved equal electrical type, compatible with operating 24-volt electric solenoid zone valves. It will feature a pump start, manual advance switch, lightning protection, manual operating mode and weatherproof turf cabinet. The included Hunter Smart Port (ROAM-WH) shall be installed on the exterior of pedestal/cabinet. Hunter ACC-COM-GPRS communication module shall be installed at all properties that are specified as Town maintained. Each controller shall have a Rain Bird WR2-RFC wireless rain/freeze click. Each controller will have a minimum of four (4) extra stations, and will not exceed forty-eight (48) stations. Controllers

will be properly grounded with an eight (8) foot ground rod. When the controller is not installed in a pump house, it will be mounted on a turf pedestal and enclosed in a strong box or similar type enclosure if needed. All installation shall be in accordance with the Standard Drawings

1052.11 Zone Valves

The zone valves will be direct burial, diaphragm type with a contamination-proof filter, a flow control and a manual bleed screw, such as the Rainbird PEB series, for “dirty water” applications PESB-R valves shall be used. They will be operated with a twenty-four (24) volt solenoid and will be capable of allowing compressed air to flow through them. All zone valves will be placed in a locking Rain Bird or equal valve box approved by the Parks & Recreation Director. Install valve at proper depth so that the top of the flow control handle is one (1) to three (3) inches from the bottom of the valve box lid. All valves will be installed with a PVC, true-union ball valve upstream of valve, and a PVC union downstream of valve, in valve box over three (3) inches depth of three-quarter (¾) inch gravel. Install only one valve per valve box. Install all valve boxes a minimum of twelve (12) inches apart, and at least twelve (12) inches from and aligned with all adjacent walls or pavement edges. Stamp all valve box lids with corresponding controller station number.

All valve boxes must be installed plumb and level with finish grade and in accordance with the Standard Drawings.

1052.12 Heads

In turf areas, Rain Bird Falcon6504-NP(NP if used with non-potable water), 8005-NP, 5004-PL-PC(FC)-SAM-R-NP-, and 5500-NP or approved equal gear driven rotary heads will be used. Each head will be installed on a swing joint consisting of schedule forty (40) PVC fittings and schedule eighty (80) PVC nipples. Swing pipe is not permitted on any gear driven rotors Heads installed in Town-maintained and Town-owned, HOA-maintained sites must be stainless steel (designated with SS). For all other applications, plastic heads are acceptable. Heads must be installed plumb and level with finish grade and in accordance with the Standard Drawings.

In small turf areas where pop-up spray heads are needed, Rain Bird 1806 SAM-PRS series or approved equal will be used. In turf areas with head spacing between fifteen (15) and Thirty (30) feet, Hunter’s MP Rotator nozzle paired with PROS-06-PRS40-CV body will be used. No VAN adjustable nozzles unless in approved locations. Heads must be installed plumb and level with finish grade.

In shrub and flower beds, Rainbird 1812 SAM-PRS or equivalent heads will be used. They will have a minimum pop-up height of twelve (12) inches, and will be installed using the bottom inlet. In some cases, bubblers may be permitted with approval of the Parks & Recreation Director.

All threaded joints will be assembled using two (2) wraps of Teflon tape. No Marlex type fittings will be allowed. The type of heads used in any particular area shall be approved by the Parks & Recreation Director or designee.

Swing pipe may be used only on Rain Bird 1800 series pop up spray heads. Use Rain Bird spiral barb fittings.

All other sprinkler heads are to be mounted on swing joints using schedule forty (40) PVC fittings and schedule eighty (80) nipples. Swing pipe is not permitted on any gear driven rotors.

Pre-made swing joints may only be used with prior approval upon inspection before installation.

1052.13 Field Wiring

Lead wire: For runs less than seven thousand seven hundred (7,700) feet, the lead wire connecting the valves to the controller shall be #14 UF single strand, direct burial, PVC jacketed, copper wire with the insulation being red in color throughout the entire jacket. For runs in excess of seven thousand seven hundred (7,700) feet, the lead wires shall be #12 UF. A minimum of four (4) spare wires will be pulled and will be of a different color (yellow).

Common wire: All common wire shall be #12 UF single strand, direct burial, PVC jacketed, copper wire with the insulation being white in color throughout the entire jacket. One spare common wire will be pulled and shall be of a different color (black). Where multiple controllers are used, a separate common wire will be installed for each controller.

Connectors: 3M's DBYR6 (or approved equivalent) water resistant connectors will be used in making wire connections. All wire connections must be made above ground, in valve boxes. A 10 inch-round valve box is the minimum size for all wire splice housing.

All wire shall be taped every 10 feet and coiled with a 36 inch coil every 100 feet and at every change in direction of main line.

1052.14 Pipe

All pipe will be continuously and permanently marked showing the manufacturer's name, the size, and the class of the pipe. All PVC pipe will conform to the requirements of the United States Department of Commerce commercial standard Type 1-ASTM-D-2241 and in accordance with the Standard Drawings.

The velocity of the water through PVC pipe shall not exceed five (5) feet per second. The velocity of the water through copper pipe shall not exceed nine (9) feet per second. The velocity of water used for temporary irrigation systems (either above or below ground) shall not exceed nine (9) feet per second.

Irrigation system piping shall be as follows:

Primary water service line (from Town water main to water meter) shall be as described in Section 642.02, Service Lines, of these STANDARDS AND SPECIFICATIONS.

Secondary water service line (from water meter to backflow preventer) shall be either ductile iron as specified in Section 632.02, Pipe, of these STANDARDS AND SPECIFICATIONS, or type "K" rigid copper. All copper fittings shall be soldered together using silver solder (brazing) using solder consisting of 45% silver, 15% copper, 16% zinc, and 24% cadmium and solids at 1125~F and liquids at 1145~F.

The irrigation main pipe shall be SDR21-200 PVC pipe. It will be assembled using ASTM F-656 purple primer followed with heavy bodied ASTM D-2564 glue. All PVC main line from one (1) inch through two and one half (2 ½) inches diameter shall be solvent weld type. All PVC main three (3) inches diameter or larger shall be connected using ductile iron fittings. Pipe shall be provided with proper thrust blocks or restraints as recommended by the manufacturer and as may be required by Section 633.06, Thrust Blocks, Restrained Joints and Fittings, of these STANDARDS AND SPECIFICATIONS.

The lateral lines shall be Class 200 PVC pipe. It will be assembled using the same primer and glue noted in "C" above.

No main line pipe shall be smaller than one inch (1").

1052.15 Quick Coupler Valves

Each system will have a minimum of one quick coupler valve located adjacent to the downstream side of the backflow preventer. This valve will be a Rainbird No.44QC (or approved equivalent). It will be installed in a ten (10) inch diameter round locking valve box as manufactured by Rain Bird over 3" of ¾" gravel. All quick couplers will be installed with a swing joint. All quick couplers will be staked with re-bar secured to the quick coupler with two (2) stainless steel screw clamps to prevent turning or twisting during use. Installation shall be in accordance with the Standard Drawings

1052.16 Stop and Waste Valve

All main lines will have a stop and waste valve installed on the upstream side of the backflow preventer. Recommend stop and waste valve be installed with compression type S&W (Mac - Pac).

1052.17 Isolation Valves

Isolation valves shall be installed at locations noted on the accepted plans or as required by the Town Engineer and in accordance with the Standard Drawings. Isolation valves two (2) inches and larger shall be Matco or acceptable substitute, and conform to the requirements of Section 632.05, Gate

Valves, and Section 642.11, Valves For Use With Meter, of these STANDARDS AND SPECIFICATIONS. Isolation valves will have a square operating nut and resilient seat.

Install isolation valve in a separate 10" Rain Bird round locking box with stand pipe over a three (3) inch depth of three-quarter ($\frac{3}{4}$) inch gravel for each assembly.

1052.18 Pressure Reducing Valves

When the Town main line static pressure exceeds ninety (90) psi, a Watts pressure reducing valve shall be installed downstream from the reduced pressure backflow preventer and in accordance with the Standard Drawings. All applicable portions of Section 632.07, Pressure Reducing Valves, of these STANDARDS AND SPECIFICATIONS, shall apply.

1052.19 Sleeving

All piping shall be sleeved under sidewalks, curbs, roadways, or similar structures. Sleeves shall be placed in an excavated trench that provides the proper alignment for the pipe. Trenches shall be excavated and compacted in accordance with Section 660.00, Trenching, Backfilling and Compacting, of these STANDARDS AND SPECIFICATIONS, prior to the installation of any sidewalks, curbs, roadways or similar structures.

Sleeves shall be PVC SDR-26 or heavier pipe and shall be double the size of the pipe to be installed through it. Sleeves shall extend a minimum of twelve (12) inches beyond the edge of the sidewalk, curb, roadway or similar structure.

1052.20 Drip Irrigation

Rain Bird Xerigation (or approved equivalent) drip irrigation components will be used. Xeribug emitters and pressure compensating nozzles, Xeri tube distribution line, and Rainbird one-quarter ($\frac{1}{4}$) inch distribution tubing will be used. Bug caps shall be installed in distribution tubing. Valve assemblies will consist of a PVC true-union ball valve, inline Basket filter and Rainbird PEB Valve assembly model X CZ-100-PRB-COM a pressure regulating device and PVC union must be installed downstream of valve and in accordance with the Standard Drawings.

Drip lateral lines to shrub beds will consist of 160 1" class PVC solvent weld pipe or eighty (80) psi 1" Commercial Poly pipe. PVC insert fittings for poly pipe or Rain bird compression fittings will be used at distribution line connections.

All clamps shall be stainless steel screw clamps, no pinch clamps.

All drip lateral lines will be minimum of $\frac{3}{4}$ ". (No 1.2" drip lines is allowed in the Town of Erie.)

A flush cap will be installed at the end of each distribution line. Install flush cap in appropriate round box over three (3) inches of three-quarter ($\frac{3}{4}$) inch gravel.

Use manufacturer’s guidelines to determine flow rate, number of emitters and water application rate for each plant. Place emitters so that they are evenly spaced around the plant. Distribution lines will not exceed two hundred and fifty (250) feet in length. System must be designed to provide at least a minimum of 15PSI available at the end of each tubing run to flush the system. Place emitters halfway between the main trunk of the plant and the edge of its canopy. Design approach of drip irrigation installation will be specific to soil type, the type of plants used, their water requirements and the suitability of the components in the landscape.

Drip laterals minimum of 12” deep in paved, sodded, seeded areas.

Where drip laterals enter shrub beds from turf areas, elbow up to finish grade. All drip irrigation components will be installed below finish grade of beds. Where mulch or rock are used with landscape fabric, place distribution lines under the fabric with a minimum of 4” of rock or mulch. Secure distribution tube with galvanized tie down stakes.

Do not use risers, bubblers, or any drip components that extend above finish grade of beds.

1052.21 Fittings

Steel-reinforced, PVC fittings shall be used on all female, threaded, mainline connections less than three (3) inches, including the upstream side of the valve assembly. Ductile iron fittings shall be used on all mainline fittings three (3) inches or greater. True-union, PVC ball valves shall be used on the upstream side of valve assemblies, and PVC unions shall be used on the downstream side of valve assemblies.

1053.00 Site Conditions

The Contractor will coordinate his work with that of other trades whenever possible to prevent conflicts. Before starting work, the Contractor will inspect the site and check all grades to ensure that he may safely proceed. All scaled dimensions are approximate. Before proceeding with any work, the Contractor will carefully check and verify all dimensions.

Changes or alterations in the system to meet site conditions will be subject to the approval of the Town Engineer and will be made at the Contractor’s expense. If any work requires that it be installed in locations other than shown in the accepted plans, the Contractor will prepare a set of “as built” drawings in accordance with Section 161.00, Construction Plan Requirements, of these STANDARDS AND SPECIFICATIONS, noting the exact locations of those changes. Exact measurements of buried valves and wire locations will be shown. The Contractor will supply the “as built” Mylar to the Town prior to receiving final acceptance. “As-built” drawings will be completed daily and kept on site for review and inspection during construction.

The Contractor will be responsible for all costs incurred for supplying the electrical needs required for the job. Xcel Energy or United Power should be contacted for information on possible electrical

sources. All electrical work, except twenty-four (24) volt, will require a separate inspection from the Town Building Official.

All applicable portions of Section 1000.00, Site Work and Earthwork, of these STANDARDS AND SPECIFICATIONS, shall apply.

1054.00 Excavation

All applicable portions of Section 660.00, Trenching, Backfilling and Compacting, of these STANDARDS AND SPECIFICATIONS, shall apply. When approved by the Parks & Recreation Director, trench excavation and backfill for irrigation systems in excess of the limits noted in Section 660.00 may be allowed.

1055.00 Process

Staking: Prior to excavating or trenching, the Contractor will stake all proposed and existing utilities and all sprinkler head and line locations. Stakes will be suitable wooden stakes color coded for materials and maintained throughout the sprinkler installation process.

Pump house: When a pump house is used, the secondary water service line shall be extended a minimum of twenty-four (24) inches below grade on the discharge side of the pump house and a minimum of twenty-four (24) inches beyond the pump house slab or footing.

Pipe assembly: The adaptation from copper to PVC will be made by using a female copper adapter receiving a male PVC adapter.

PVC pipe shall be assembled in accordance with Section 1052.14, Pipe, of these STANDARDS AND SPECIFICATIONS. All excess glue will be wiped from the joint with a cloth rag or similar material after assembly.

All threaded PVC fittings and nipples shall receive a double wrap of Teflon tape prior to assembly.

Trenching: All pipe will be installed in an excavated trench. Trenches will be dug true to the alignments shown on the accepted plans. Excavation of the trenches will be done in a workman-like manner, providing a trench that is straight and true with a flat bottom containing no rocks or other deleterious material that may damage the pipe.

Separate trenches will be dug for each line. No doubling up of lines in a single trench will be allowed. Trenches will be dug deep enough to allow the following cover over the top of the pipe:

Main Line Size	Minimum Cover	Maximum Cover
1" - 1-1/2"	24"	24"

Main Line Size	Minimum Cover	Maximum Cover
2" - 3"	24"	36"
Greater than 3"	36"	48"

Lateral Line Size		Minimum Cover	Maximum Cover
1" - 3"	(where rotors are used)	18"	24"
1" - 3"	(where spray heads 4" - 8" pop up height are used)	12"	24"
1" - 3"	(where spray heads 12" or over pop-up heights are used)	18"	24"

No trench will be left open overnight without specific prior approval by the Parks & Recreation Director or designee and without sufficient barricades to protect the public. Barricades shall meet the requirements of Section 141.08, Traffic Control, Barricades and Warning Sign, of these STANDARDS AND SPECIFICATIONS and in accordance with the Standard Drawings.

Control valves: Control valves will be installed in valve boxes with the top of the flow control stem one (1) to three (3) inches below the bottom of the valve box lid. Whenever possible, electric valve control wires will be buried under and to one side of the main line. All wire will be buried deep enough to maintain a minimum cover of thirty-six (36) when not buried with the mainline, and a minimum of twelve (12) inches of slack for both the lead wire and the common wire will be provided within each valve box. Multiple valves on a single control wire are prohibited. Warning tape will be installed over wiring at any location where wiring is not installed adjacent to mainline.

Backfill: All backfill material will be free of rocks one (1) inch in diameter and larger. Backfill shall be completed in accordance with Section 660.00, Trenching, Backfilling and Compacting, of these STANDARDS AND SPECIFICATIONS.

Turn on and winterization: The Contractor shall winterize the system in the fall, put it into operation in the spring, and perform all other necessary service work needed to insure proper operation of the system.

1056.00 Inspections

Inspections shall be completed in accordance with Section 1024.00, Inspections, of these STANDARDS AND SPECIFICATIONS. The Contractor must notify the Town for inspections of sprinkler location staking, main line installation, wiring installation and coverage test.

1056.01 Sprinkler Location Staking

The Town will inspect the staked locations of all lines and heads for conformance to the accepted plans and these STANDARDS AND SPECIFICATIONS. The Town reserves the right to move, shift and adjust any of the stakes to better achieve the design intentions as shown on the accepted plans. No trenching will be done until the inspection is complete and the staked locations accepted by the Town.

1056.02 Main Line Inspection

The Town will inspect the depth of pipe, manual drain valves, sumps and control valves for conformance to the accepted plans and these STANDARDS AND SPECIFICATIONS prior to covering the pipe. All main lines will be pressure tested in accordance with Section 633.14, Leakage, of these STANDARDS AND SPECIFICATIONS.

1056.03 Wiring Inspection

When the wiring installation has been completed, the Town will inspect it for conformance to the accepted plans and these STANDARDS AND SPECIFICATIONS.

1056.04 Coverage Test

After the sprinkler heads have been installed and backfilling operations are complete and prior to ordering any sod or seed, the Contractor, in the presence of the Town, will perform a coverage test to determine the conformance to the accepted plans and these STANDARDS AND SPECIFICATIONS. No partial acceptance will be made.

1056.05 Pressure Test

Sprinkler mains will be pressure tested for two (2) hours at one hundred and twenty (120) psi, and shall be observed by the Town Inspector. No leakage or pressures losses shall be accepted. Leakage will be detected by hydrostatic testing and visual inspection. Cement or caulking to repair leaks is prohibited. Repeat test until all leaks are corrected.

1057.00 Warranty Period

The Contractor shall be responsible for the entire sprinkler system for a period of two (2) years from the date of acceptance of the entire project. If any trouble should develop within this time period due to faulty workmanship or material, the defect will be corrected in a timely fashion by the Contractor without expense to the Town. The Contractor will not be responsible for repair of the sprinkler system due to vandalism or due to erosion after the work has been accepted by the Town.

Repair damages to the premises caused by defective items within a maximum of five (5) days of notification from the owner.

Make adjustments, repairs and replacements at no additional cost to the contract price.

System must provide head to head coverage. Contractor will guarantee head to head coverage and make any adjustments or field changes to ensure proper coverage during construction or during the warranty period at no additional cost to the contract price.

Any settling of backfilled trenches, which may occur during the guarantee period, will be repaired without expense to the Town, including the complete restoration of all damaged property.

Turn on and winterization: The Contractor shall winterize the system in the fall, put it into operation in the spring, and perform all other necessary service work needed to insure proper operation of the system.

Approved construction drawings shall be on site daily and updated weekly with As Built markups. Contractor will make As Builts available for review and inspection to Town staff on site at all times on request. Record all changes which are made from the contract drawings. Irrigation As Builts will identify and record dimensioned locations for all components installed in valve boxes and locate all dimensions from two permanent reference points. Record all required information on as built drawings. Do not use these prints for any other purpose.

1060.00 PLANTING SPECIFICATIONS

1061.00 General

The scope of work involves furnishing all plants, equipment, materials, labor and supervision necessary for the installation of plant materials as indicated on the accepted plans and in these STANDARDS AND SPECIFICATIONS.

1062.00 Materials

1062.01 Wood and Rock Mulch

Wood chip mulch shall be of a high quality fibrous nature, such as shredded wood chips or shavings, which are between one (1) inches and four (4) inches in length. Mulch shall be clean and free of soil, chipped invasive plant species, or man-made debris and shall be uniformly placed at a depth of three inches.

Rock mulch shall be clean and be between, three-quarter (3/4) to two (2) inch rounded, washed river rock. Rock Cobble shall be 2 – 4 inch or 3 – 6 inch washed cobble. Rock Mulch and Cobble shall be clean and free of soil or man-made debris and shall be of good quality. All Rock mulch or Cobble samples shall have the size, product name and supplier listed with the sample provided.

Larger rock cobble four to eight inches (4-8”) may be suitable for areas where plant materials are not planned and may be considered by Town staff on a case-by-case basis. The Parks and Recreation Director or his designee will make this allowance if applicable.

Different mulch types shall be separated by three-sixteenths (3/16) inch wide by six (6) inches deep green painted steel edger. Formal shrub beds shall exclusively utilize rock mulch. Shrub beds which consist solely of perennials, native shrubs and/or trees shall exclusively use wood chip mulch.

1062.02 Organic Amendments

Class One organic material will be dry, well-rotted, minimum one (1) year old poultry, horse, sheep or dairy cow manure. Manure will be free of sawdust, wood chips, and excessive salt and chemical additives. See Standards and Specifications sections 1022 and 1023 for further information.

1062.03 Landscape Fabric

All landscape fabric shall be Typar 3401 4 ounce/sq. yard geo-textile polypropylene fabric or an approved equivalent.

1062.04 Edging

All edging shall be three-sixteenths (3/16) inch wide by six (6) inches deep green painted steel. Use of approved steel edging is required to separate bluegrass with formal shrub plantings, perennial plantings and irrigated native shrub plantings. No edger is necessary with non-irrigated native shrub or tree plantings.

1062.05 Staking and Guying

All trees shall be staked and guyed using the following material:
Stakes: Six (6) foot steel tee posts for deciduous trees; two (2) foot steel tee-posts for coniferous trees. Straps to be DeepRoot, ArborTie7 or Town-approved equivalent; flat, woven polypropylene, with 900 pound (or greater) break strength; green in color.

1062.06 Submittals

Contractor shall furnish material samples (mulch, sod, stone, compost and soil amendments, etc.) on request by the Town.

1062.07 Trees and Shrubs

The Contractor will furnish and install all plants shown on the accepted plans. All plant material shall conform to the measurements as noted in the size requirements and on the accepted plans. Nursery stock shall meet the minimum dimensions for height and/or caliper. All plant material shall comply with the American Standard for Nursery Stock ANSI Z60.1-2004 at installation and throughout the project warranty period.

Distribution of Tree Species

Tree diversity is necessary to prevent uniform insect or disease susceptibility and extensive monocultures. Deciduous trees shall constitute at least fifty (50) percent of all tree plantings to any development plan. Tree diversity shall follow the minimum requirements on any development plan:

<i>Number of trees on site</i>	<i>Maximum percentage of any one species</i>
10-19	50%
20-39	33%
40-59	25%
60 or more	15%

NO Ash (*Fraxinus spp.*) trees will be approved for planting by the Town on any Town-owned property due to the threat of Emerald Ash Borer.

Size Requirements

All deciduous and ornamental trees shall be one and one-half (1.5) inch caliper or larger. Caliper measurement shall be taken six (6) inches above the root flare if four (4) inches or less and twelve (12) inches above the root flare for larger tree sizes.

All evergreen trees shall be a minimum of six (6) feet tall or larger. Height dimensions refer to the main body of the tree, from the root collar and above.

Shrubs shall be number five (5) size containers or larger. Smaller containerized stock or dormant bare root shrubs and trees may be planted at the edge of drainages in native areas.

Perennials and groundcovers shall be number one (1) size container or larger

Quality

Trees shall be typical of their species and/or variety. Plant materials shall be live, healthy, vigorous, structurally sound, and free of disease and insect infestations.

Trees shall have a symmetrical form as typical for the species/cultivar. Trees must be self-supporting and shall have a single, relatively straight central leader and tapered trunk, free of co-dominant stems and vigorous, upright branches that compete with the central leader. The tip of the dominant leader shall be the tallest part of the tree.

Branches shall be distributed radially around and vertically along the trunk, forming a symmetrical crown typical for the species. Branches shall be no larger than two-thirds (2/3) the diameter of the trunk. The attachment of scaffold branches shall be free of included bark. Evergreens shall have branches that extend to the ground. Trees shall be free of twig and/or branch dieback

Plants shall exhibit good annual growth and buds shall be plump and well fitted for the species. Foliage shall be full and display a healthy and consistent color when in leaf. Evergreen foliage will be good intense color.

Trees shall be free of wounds (except properly-made pruning cuts), disfiguring knots, sunscald injury, evidence of previous or current disease or insect infestations, fungal fruiting-bodies, wood cracks, and bleeding areas.

Plant tags stating the correct plant name and size will be securely attached to all plant materials. Plants shall be true to their name as specified.

Balled and Burlapped trees shall have a solid ball of earth of minimum or greater specified size (see enclosed chart below) firmly wrapped with burlap or similar materials and held in place securely bound with twine or rope. No balled plant will be planted if the ball is broken, either before or during the planting process. Any plant that is loose in the ball will be removed from the site and replaced.

The minimum ball size for B & B trees is as follows:

Tree Size	Ball Depth Minimum	Ball Diameter Minimum
1½” - 2” caliper	18”	22”
2” - 2½” caliper	20”	24”
2½” - 3” caliper	22”	28”
3½” - 4” caliper	30”	38”
5’ - 6’ height	14”	16”

Container grown trees shall be well rooted and established in the container in which they are growing. They shall be grown in the container for a sufficient length of time for the root system to hold the earth when taken from the container, but not long enough to become pot bound. They should have few, if any, roots on the outside surface of the media. The root collar and large roots shall be free of circling and/or kinked roots. The upper-most roots or root collar shall be within one (1) inch above or below the soil surface. The soil level should be within two (2) inches of the top of the container. Containers shall be stable and not deteriorated to a degree that will cause breaking up of the root ball during the planting operations.

Bare-root trees shall have a heavy fibrous root system that has been developed by proper cultural treatment, transplanting and root pruning. The spread of the root system shall be twelve (12) times the trunk diameter (caliper) in inches, plus an additional six (6) inches. Any damaged, injured, or broken roots shall be cut with sharp, clean pruning shears, leaving no damaged, frayed, or splintered cut surfaces.

Plant materials not meeting these standards are subject to rejection.

Town of Erie/Front Range Tree Recommendation List

The Town of Erie has adopted the Front Range Tree Recommendation List. Additional trees may be added to the list upon a determination that the trees are appropriate for inclusion. Contact the Parks Division for approval of trees that are not listed. The Town reserves the right to make recommendations and substitutions of tree species and varieties during the plan review phase to address species diversity, site conditions, and maintenance needs.

Trees are grouped into the following categories:

A - Generally Recommended

B - Conditionally Recommended

C - Potential/Unproven

D - Not Recommended

- Select trees from the “A list” (Generally Recommended) or the “B list” (Conditionally Recommended) where the limiting critical factor(s) can be managed.
- When selecting trees from the “C list” (Potential/Unproven), use limited quantities appropriate for the site.
- Do not use trees from the “D list” (Not Recommended)

Thoroughly research all trees before ultimately choosing a tree to assure that the species you select is suitable for the desired site in regards to mature sizes and growing conditions. Size at maturity figures are estimates and can be highly variable depending on the variety or cultivar chosen.

All trees on this list are suitable for planting on private and public properties, **with the exception that there is a moratorium of planting any ash trees (*Fraxinus spp.*) on any Town-owned property due to the threat of Emerald Ash Borer.**

All street tree species and their locations shall be approved by the Parks & Recreation Director or designee for trees planted adjacent to residential homes, whether they be installed by the developer/contractor or individual homeowner. Ash trees shall not be planted under any circumstances.

Only thornless tree varieties species shall be planted in any public access areas.

When selecting tree species consider:

•Soil type, growth rate, water requirements, site use, hardiness, litter potential (leaves, fruit,

DECIDUOUS ALPHA-BOTANIC																			
Plant Nomenclature from Manual of Woody Landscape Plants by Michael A. Dirr 2009 edition.			Critical					Cautionary					Other						
			SC	ST	ID	CH	SA	TS	WW	SL	SU	RS	TR	LS	EX	WN	LA		
<i>Acer</i>	Maple																		
<i>Acer campestre</i>	Hedge	B				x											l-m	x	Variable hardiness from seed; prone to winter dieback in hard early freezes
<i>Acer x freemanii</i>	Freeman - 'Armstrong', Autumn Blaze®, Autumn Fantasy®, Celebration®, Sienna Glen®	B	x				x	x									m		Develops chlorosis in alkaline soils
<i>Acer ginnala</i>	Amur/ Ginnala - 'Flame'	B	x				x					x					l-m		Can develop chlorosis in alkaline soils
<i>Acer glabrum</i>	Rocky Mountain	B		x													m-h		Prefers more moisture
<i>Acer grandidentatum</i>	Big Tooth	A															l-m	x	
<i>Acer grandidentatum</i>	Big Tooth - Manzano™	C				x											l-m	x	More tree-like than <i>Acer grandidentatum</i>
<i>Acer griseum</i>	Paperbark	C				x							x		x		m	x	Needs a protected site; does not transplant well when bare rooted
<i>Acer miyabei</i>	Miyabe	C				x			x								l-m	x	Typically budded to <i>A. campestre</i> that shows variable hardiness from seed
<i>Acer negundo</i>	Boxelder/ Ash-leaved - 'Sensation'	C							x								l-m	x	Tolerant of alkaline soils; holds a strong dominate leader; male tree so no boxelder bugs
<i>Acer palmatum</i>	Japanese	B	x	x		x				x						x	m-h		Prefers well drained soils low in salt content with some protection
<i>Acer platanoides</i>	Norway - 'Columnare', 'Crimson King', 'Crimson Sentry', 'Deborah', Emerald Lustre®, 'Emerald Queen', Fairview®, 'Royal Red'	B							x							x	m		<i>Acer platanoides</i> is prone to sunscald and leaf scorch in hot dry sites

acorns, cones, or pods), mature size relative to utilities, structures, and site conditions. site exposure, texture, slope of grade, possible microclimates ,insect and disease susceptibility, invasiveness potential, allelopathic properties, allergic potential to property users, toxic plant parts, wildlife use/misuse, hazardous growth (thorns, prickly leaves)

•Rooting space, soil type and texture, drainage, utility conflicts, hardscapes/structural conflicts, and purpose of tree

CRITICAL: SC=Soil Chemistry · ST=Soil Texture · ID=Insects & Diseases · CH=Cold Hardiness · SA=Salt Tolerance

CAUTIONARY: TS=Tree Wrap/Sunscald · WW=Weak Wood · SL=Short Lived · SU=Suckers · RS=Re-seeds · TR=Transplants · LS=Leaf Scorch · EX=Exposure

OTHER: WN=Water Needs · LA=Limited Availability

Deciduous Trees

PARKS AND RECREATION CONSTRUCTION

SECTION 1000

<i>Malus</i> 'Haralred'	Haralred	B				x															m	Good northern apple, subject to codling moth
<i>Malus</i> 'Honeycrisp'	HoneyCrisp	C																			m x	Subject to codling moth
<i>Malus</i> 'Jonathan'	Jonathan	B			x																m	Fireblight, subject to codling moth
<i>Malus</i> 'Liberty'	Liberty	C																			m	Subject to codling moth
<i>Malus</i> 'McIntosh'	McIntosh	B			x																m	Fireblight, subject to codling moth
<i>Malus</i> 'Red Delicious'	Red Delicious	A																			m	Subject to codling moth
<i>Malus</i> 'Royal Gala'	Royal Gala	B			x																m	Fireblight, subject to codling moth
<i>Malus</i> 'Sweet Sixteen'	Sweet Sixteen	C																			m	Northern selection, subject to codling moth
<i>Malus</i> 'Yellow Delicious'	Yellow Golden Delicious	A																			m	Subject to codling moth
<i>Malus</i> 'Zestar'	Zestar	C																			m x	Subject to codling moth
Malus	Crabapple																					
<i>Malus</i> 'Adams'	Adams	A																			l-m x	
<i>Malus</i> x 'Branzam'	Brandywine®	B			x																l-m	Large messy fruits, firelight
<i>Malus</i> x 'Centzam'	Centurion®	A																			l-m	Disease resistant
<i>Malus</i> x 'Coralcole'	Coralburst™	A																			l-m	Disease resistant
<i>Malus</i> 'David'	David	A																			l-m x	
<i>Malus</i> 'Dolgo'	Dolgo	B			x																l-m x	Messy fruit; fireblight
<i>Malus</i> x 'Schmidtcutleaf'	Golden Raindrops®	D			x																l-m x	Some fireblight
<i>Malus</i> 'Hopa'	Hopa	B			x																l-m x	Some fireblight, messy fruit
<i>Malus</i> 'Indian Magic'	Indian Magic	A												x							l-m	Poor structure
<i>Malus</i> 'Indian Summer'	Indian Summer	A																			l-m	
<i>Malus ioensis</i>	Bechtel 'Plena'	D			x																l-m x	Fireblight
<i>Malus</i> 'Prairiefire'	Prairiefire	B			x																l-m	Fireblight
<i>Malus</i> 'Prairie Rose'	Prairie Rose	C																			l-m x	
<i>Malus</i> 'Profusion', 'Radiant'	Profusion, Radiant	A																			l-m	
<i>Malus</i> 'Red Barron'	Red Barron	C																			l-m x	Fireblight
<i>Malus</i> 'Red Jade', 'Royalty'	Red Jade, Royalty	D			x																l-m x	Fireblight
<i>Malus</i> 'Robinson', 'Royal Raindrops'	Robinson, Royal Raindrops	C																			l-m x	
<i>Malus sargentii</i>	Sargent	A			x																l-m	
<i>Malus sargentii</i> 'Tina'	Sargent Tina	C																			l-m	
<i>Malus</i> 'Spring Snow'	Spring Snow	A			x																l-m	Some fireblight
<i>Malus</i> 'Thunderchild'	Thunderchild	A																			l-m	
<i>Malus</i> 'Velvetcole'	Velvet Pillar™	C																			l-m x	
Morus alba	White - 'Chaparral'	B				x								x							m	Some dieback
<i>Phellodendron amurense</i>	Amur corktree	C																			m x	
<i>Platanus x acerifolia</i>	London Planetree - 'Bloodgood'	C			x	x															x m-h	Anthraco-nose
Populus	Poplar (cottonwood)																					
<i>Populus angustifolia</i>	Narrowleaf	B			x									x	x	x					l-m	Vigorous suckering; forms colonies. Use in native areas only
<i>Populus deltoides</i>	Eastern	B			x									x	x	x					m-h	Too big for residential use
<i>Populus sargentii</i>	Plains	A												x							m-h	Too big for residential use
<i>Populus sargentii</i>	Sargent, Straight Plains 'Jeronymus'	A																			m	Too big for residential use
<i>Populus tremula</i> 'Erecta'	Upright European, Aspen	B			x																m	Unique form; prone to many diseases and insects
<i>Populus tremuloides</i>	Quaking Aspen	B			x																m	Better at high elevations, chlorosis at lower elevations, prone to many diseases & insects
<i>Populus x acuminata</i>	Lanceleaf	A												x	x						m	Too big for residential use
<i>Populus x acuminata x sargentii</i>	Highland	B			x									x	x						m	Too big for residential use
<i>Populus x canescens</i> 'Tower'	Tower	D			x									x	x						m x	Prone to many diseases and insects
Prunus	Apricot																					
<i>Prunus armeniaca</i>	Chinese	A																			m x	Seldom sets fruit along the front range
<i>Prunus armeniaca</i>	'Moongold', 'Moorpark'	A																			m x	Great fall color; seldom sets fruit along the front range

Evergreen Trees

EVERGREEN ALPHA-BOTANIC																		
Plant Nomenclature from Manual of Woody Landscape Plants by Michael A. Dirr 2009 edition.			Critical				Cautionary						Other					
			SC	ST	ID	CH	SA	TS	WW	SL	SU	RS	TR	LS	EX	WN	LA	
<i>Abies concolor</i>	White	B	x			x	x									m		Needs more moisture; needs well drained soil; chlorosis
<i>Cedrus libani</i>	Cedar of Lebanon	C		x												m	x	
<i>Juniperus</i>	Juniper																	
<i>Juniperus chinensis</i>	Chinese - 'Blue Point', 'Spartan', 'Spearmint'	B		x		x									x	l-m		
<i>Juniperus chinensis</i>	Chinese - 'Hetzi Columnaris'	A														l-m		
<i>Juniperus monosperma</i>	One -Seed	A														l	x	Needs a dry site.
<i>Juniperus osteosperma</i>	Utah	A														l	x	Needs a dry site.
<i>Juniperus scopulorum</i>	Rocky Mountain	A														l	x	
<i>Juniperus scopulorum</i>	Rocky Mountain - 'Welchii', 'Gray Gleam', 'Cologreen', 'Sky Rocket', 'Wichita Blue' 'Moonglow', 'Medora'	A														l		
<i>Juniperus virginiana</i>	Eastern Red Cedar - 'Hillspire', 'Idyllwild', 'Blue Arrow', 'Taylor'	A													x	l-m		Will not take windy sites
<i>Juniperus virginiana</i>	Eastern Red - 'Manhattan Blue'	A													x	l-m	x	
<i>Larix decidua</i>	European Larch	B														m-h		
<i>Metasequoia glyptostroboides</i>	Dawn Redwood	C		x		x									x			
<i>Picea</i>	Spruce																	
<i>Picea abies</i>	Norway - 'Cupressina'	B													x	m-h		Will not take windy sites; needs a more protected area
<i>Picea glauca</i>	Black Hills 'Densata'	A														m-h	x	
<i>Picea omorika</i>	Serbian	B		x		x										m-h	x	
<i>Picea pungens</i>	Colorado	A			x											m-h		Tussock moth in large trees
<i>Picea pungens glauca</i>	Colorado Blue - 'Baby Blue Eyes', 'Bakeri', 'Fastigiata', 'Fat Albert', 'Hoopsi', 'Colorado Weeping', 'Sester's Dwarf'	A			x											m-h		Possible IPS problem
<i>Pinus</i>	Pine																	
<i>Pinus aristata</i>	Bristlecone (foxtail)	B				x										l-m		Slow growing
<i>Pinus bungeana</i>	Lacebark	C														m-h	x	
<i>Pinus cembra</i>	Swiss Stone Pine	C		x												l-m		
<i>Pinus contorta</i>	Lodgepole	B			x											l-m	x	Chlorosis at lower elevations; susceptible to mountain Pine Beetle
<i>Pinus edulis</i>	Pinyon	A			x											l-m		Pitch borer, tip moth, Pine Beetle.
<i>Pinus flexilis</i>	Limber	A														l-m		
<i>Pinus flexilis</i>	'Vanderwolf's Pyramid'	A														l-m		
<i>Pinus heldreichii</i>	Bosnian var. leucodermis	A													x	m	x	
<i>Pinus heldreichii</i>	Bosnian var. leucodermis - 'Emerald Arrow', 'Iseli Fastigiata'	C													x	m	x	
<i>Pinus monophylla</i>	Singleleaf Pinyon	C														l	x	
<i>Pinus mugo</i>	Mugo - 'Big Tuna', 'Tannenbaum'	A														l-m		
<i>Pinus nigra</i>	Austrian	A														m		Some Zimmerman Pine Moth
<i>Pinus nigra</i>	Austrian - 'Arnold's Sentinel'	D														m		
<i>Pinus ponderosa</i>	Ponderosa	B			x											l-m		Mountain Pine Beetle
<i>Pinus strobus</i>	Eastern White	B	x			x									x	m		Soil chlorosis-wind
<i>Pinus strobiformis</i>	Southwestern White	A														l-m		
<i>Pinus sylvestris</i>	Scotch	B			x			x								m	x	Mountain Pine Beetle
<i>Sequoiadendron giganteum</i>	Giant Sequoia - 'Hazel Smith'	C		x											x	m-h	x	
<i>Taxodium distichum</i>	Baldcypress																	
<i>Taxodium distichum</i>	Baldcypress - 'Frio River'	C		x												m-h	x	
<i>Thuja occidentalis</i>	Eastern Arborvitae - 'Emerald', 'Techny', 'Degroots Spire'	B													x	m-h		More protected area
<i>Thuja standishii</i> x <i>Thuja plicata</i>	Green Giant	B													x	m-h	x	More protected area

Street Tree Spacing Requirements & Recommendations

Small Deciduous Trees	Medium Deciduous Trees	Large Deciduous Trees
under 30’ mature height	30’ – 45’ Mature Height	Over 45’ Mature Height
12’ Minimum Spacing Between Trees, 20’ Recommended	20’ Minimum Spacing Between Trees, 30’ Recommended	30’ Minimum Spacing Between Trees, 40’ Recommended

Small Evergreen Trees	Large Evergreen Trees
Under 30’ Mature Height	Over 30’ Mature Height
12’ Minimum, 20’ Recommended Spacing Between Trees	20’ Minimum, 30’ Recommended Spacing Between Trees
Do Not Use as a Street Tree	Do Not Use as a Street Tree

Street Tree Requirements

All street trees shall conform with both the required minimum planting strip width and mature heights as detailed in the above table. A permit is required for all trees to be planted in the public right-of-way that are planted after the approved development landscape design plan. All street trees shall be pruned to meet clearance requirements above sidewalks, alleys, and streets.

The following are not acceptable as street trees:

- Russian Olive - *Elaeagnus angustifolia*
- Tree-of-heaven – *Ailanthus altissima*
- Willow - *Salix spp.*
- Poplars (Cottonwood, Aspen, Lombardy) - *Populus spp.*
- Silver Maple - *Acer saccharinum*
- Boxelder – *Acer negundo*
- Evergreens (Pines, Spruce, Fir, Arborviate, Juniper, etc.) - *Pinus spp., Picea spp., Abies spp., Thuja spp., Juniperus spp.*
- Multi-Stemmed or Clump Forms
- Any weeping and pendulous trees
- Thorn-bearing trees

Staff-Recommended Approved Trees for Native Plantings

Scientific Name	Common Name(s)	Planting Altitude	Native Colorado Life Zone	Moisture	Evergreen /	Comments
------------------------	-----------------------	--------------------------	----------------------------------	-----------------	--------------------	-----------------

		in feet			Deciduous	
Large trees (45+ ft when mature)						
<i>Abies concolor</i>	white fir, concolor fir	4,000 - 10,000	Foothills - Montane	M - H	E	Symmetrical, pyramidal shape; for large landscapes; attractive soft, blue-green needles; grows best where protected from wind.
<i>Acer negundo</i>	box-elder	4,500 - 7,500	Plains - Foothills Upper Sonoran	M - H	D	Maple with compound leaves found along streams; rapid grower, weak-wooded, short-lived; female trees attract nuisance box-elder bugs.
<i>Picea pungens</i>	Colorado spruce	4,000 - 9,500	Foothills - Montane	M - H	E	Colorado State Tree; sharp, stiff needles ranging from green to silvery blue; horizontal branching.
<i>Pinus ponderosa</i>	ponderosa pine	4,000 - 9,000	Foothills - Montane	L - M	E	Longer, yellow-green needles; bark becomes cinnamon color with age; vanilla fragrance on warm days.
<i>Pinus strobiformis</i>	Southwestern white pine	4,000 - 8,500	Foothills - Montane	L - M	E	Blue-green needles, large cones, scaly bark when mature, faster-growing, less commonly available.
<i>Populus angustifolia</i>	narrowleaf cottonwood	4,000 - 9,500	Foothills - Montane	H	D	Vertical growth habit; willow-like leaves, suckers heavily, best in natural areas along streams; males do not produce cotton; yellow fall color.
<i>Populus sargentii</i>	Plains cottonwood	4,000 - 7,000	Plains - Foothills Upper Sonoran	H	D	Fast-growing, broad, irregular canopy; triangular leaves; males do not produce cotton.
<i>Populus x acuminata</i>	lanceleaf cottonwood	4,500 - 8,500	Foothills	H	D	Fast-growing, upright, rounded, dense branching; spear-shaped, drooping leaves; less suckering; natural hybrid between Plains and narrowleaf cottonwoods; males do not produce cotton.
<i>Pseudotsuga menziesii</i>	Douglas-fir	4,500 - 11,000	Foothills - Montane	M	E	Fast-growing; soft, medium to dark green needles; pyramidal shape; unique cones; alternate host for gall insects on spruce.
Small - Medium trees (10-45 ft when mature)						
<i>Acer grandidentatum</i>	bigtooth maple, Wasatch maple	4,500 - 7,000	Foothills - Montane	L - M	D	Native to southwest, with occurrences in Montezuma County; often multi-stem form; degree of orange-red fall color varies.
<i>Alnus tenuifolia</i>	thinleaf alder	5,000 - 10,000	Foothills - Subalpine	H	D	Large shrub or small tree, often multi-stemmed; yellow fall color not reliable; persistent fruits resemble miniature pine cones, found along streams; bark gray;

						sun to part shade.
<i>Betula fontinalis</i> (<i>Betula occidentalis</i>)	Rocky Mountain birch	5,000 - 9,000	Foothills - Montane	H	D	Small tree or large shrub; bronze-red bark; found along streams, often with thinleaf alder; yellow fall color; requires additional moisture in dry winters.
<i>Juniperus monosperma</i>	oneseed juniper	4,000 - 7,500	Plains - Foothills	L	E	Multi-stemmed tree with small, scale-like leaves, found on dry rocky slopes, often with pinon.
<i>Juniperus osteosperma</i>	Utah juniper	5,000 - 9,000	Upper Sonoran - Foothills	L	E	Spreading, multi-stemmed evergreen with small, scale-like leaves; large, grayish-blue berry-like fruits are important food for small mammals & birds.
<i>Juniperus scopulorum</i>	Rocky Mountain juniper	4,000 - 8,000	Foothills - Montane	L	E	Variable growth habit, often upright to columnar; male and female flowers on separate plants; found on dry mountain slopes and mesas; berry-like fruit important food for small mammals and birds.
<i>Pinus aristata</i>	bristlecone pine	5,000 - 11,000	Montane - Subalpine	L - M	E	Rounded to pyramidal shape; branches have bottlebrush appearance; short, dark-green needles with specks of white resin; spiny cones; needs well-drained soil; slow-growing.
<i>Pinus edulis</i>	pinon, pinyon pine	4,000 - 7,500	Foothills - Montane Upper Sonoran	L	E	Compact, bushy growth form with grayish green needles in bundles of two, small rounded cones; edible seeds develop when planted in grove for cross-pollination; best in dry, well-drained site.
<i>Quercus gambelii</i>	Gambel oak, scrub oak	4,000 - 8,500	Foothills - Montane	L - M	D	Small tree to large shrub, best on well-drained soils; often thicket-forming; shades of red, orange, yellow and brown in fall; acorns provide excellent wildlife food.
<i>Salix amygdaloides</i>	peachleaf willow	3,500 - 7,000	Plains - Foothills Upper Sonoran	H	D	Fast-growing; lance-shaped leaves; new twig growth orange-yellow; ascending branches; found along streams.

Approved Shrub List

SHRUBS, ORNAMENTAL GRASSES AND PERENNIALS

Acceptable shrubs, ornamental grasses and perennials for landscaping in Erie are included in the following lists. Other plant materials may be submitted for review and approval by the Parks & Recreation Director or designee. Preference shall be given to drought resistant species. Staff also recommends using plants listed within the Plant Select® recommended list of plants. See www.plantselect.org for the most recent list of recommended plants.

Plant Name	Height (H'xW')	Growth Rate	Soil Moisture	Exposure	Comments and Cultural Hints
Arborvitae					
<i>Thuja occidentalis</i> Eastern Arborvitae					
‘Hetz Midget’	3 x 3	S	M	S to PS	Dense, globe-shaped.
‘Holmstrup’	5 x 3	S	M-H	S to PS	Compact pyramid; holds foliage color in winter.
‘Little Giant’	4 x 4	S	M	S to PS	Globe-shaped.
Juniper					
<i>Juniperus communis</i> Blueberry Delight®	2 x 6	M	L	S	Spreading & mounded with lacy bright green foliage. Spreading and mounded with tiered branching – Also known as Tammy.
‘Effusa’	4 x 8	M	L	S	
<i>Juniperus sabina</i> Savin Juniper					
‘Arcadia’	2 x 6	M	L	S	Spreading & mounded with lacy bright green foliage. Dense, mounding, dark green form. Bright green foliage on a flat top form. Spreading and mounded with tiered branching – Also known as Tammy.
‘Broadmoor’	2 x 6	M	L	S	
‘Buffalo’	2 x 6	M	L	S	
‘Tamariscifolia’	4 x 8	M	L	S	
<i>Juniperus scopulorum</i> Rocky Mountain Juniper					
‘Table Top Blue’	6 x 8	M	L	S	Silvery-blue foliage; broad, flat-topped habit.
<i>Juniperus squamata</i> Singleseed Juniper					
‘Blue Star’	3 x 4	S	L	S-PS	Silvery-blue needles arranged in a star-like pattern; compact mounded habit.
<i>Juniperus x media</i> Spreading Juniper					
‘Armstrong’	4 x 8	M	L	S	Gray-green lacy foliage on arched branches. Silver-blue foliage with wide spreading growth habit. Golden-yellow arching branch tips. Gray-green foliage; dense, spreading habit.
‘Holbert’	3 x 8	M	L	S	
‘Old Gold’	3 x 6	M	L	S	
‘Pfitzeriana Compacta’	4 x 9	M	L	S	

'Sea Green'	6 x 8	M	L	S	Mint green foliage, vase-shaped habit, also known as Mint Julep™.
Pine					
<i>Pinus densiflora</i> Japanese Red Pine 'Umbraculifera' Tanyosho Pine	10 x 10	S	M	S	Umbrella form with orange bark and medium green needles.
<i>Pinus mugo</i> Mugo Pine 'Big Tuna' 'Mops' 'Slowmound' 'Pumilio' 'White Bud'	10 x 7 3 x 3 4 x 6 6 x 8 3 x 4	S S S S S	L L L L L	S S S S S	Dense, upright habit; dark green needles. Dense, compact globe; dark green needles. Dense, compact mushroom-shaped; dark green needles. Variable habit; multi-stemmed. White buds contrast with dark green needles.
<i>Pinus nigra</i> Austrian Pine 'Hornibrookiana'	3 x 6	S	L	S	Broad shrubby form with dark green needles.
<i>Pinus strobus</i> Eastern White Pine 'Blue Shag'	4 x 4	S-M	M	S-PS	Globe-shape form with blue-green foliage. May turn yellowish in alkaline soils.
<i>Pinus sylvestris</i> Scotch Pine 'Albyn Prostrata' 'Glauca Nana' 'Hillside Creeper' 'Pumila'	3 x 8 8 x 6 3 x 8 10 x 6	S-M S M S-M	L L-M L-M L-M	S S-PS S-PS S-PS	Spreading form with shiny green needles. Dense, rounded habit; blue-green needles. Spreading form with medium green needles that become lighter in winter months. Broad, upright habit; bluish-green needles.
Spruce					
<i>Picea abies</i> Norway Spruce 'Elegans' 'Nidiformis' 'Pendula' 'Pumila'	4 x 6 3 x 5 6 x 8 4 x 5	S S S S	M M M M	S-PS S-PS S-PS S-PS	Nest-shaped with short needles. Nest-shaped with short green needles. Weeping habit, short dark green needles. Compact, nest-shaped mound with dark needles.
<i>Picea glauca</i> White Spruce 'Conica' Dwarf Alberta Spruce	8 x 4	S	M	S-PS	Dense, conical shape with short green needles; best with winter protection.
<i>Picea pungens</i> Colorado Spruce 'Globe' 'Mesa Verde' 'St Mary's' Broom' 'Walbrunn'	3 x 4 2 x 5 3 x 4 3 x 4	S S S S	M M M M	S-PS S-PS S-PS S	Globe-shaped with green needles. Nest-shaped with green needles. Globe-shaped with blue-green needles. Nest-shaped with blue green needles.

Yew					
<i>Taxus cuspidata</i> Japanese Yew 'Monloo' Emerald Spreader™	3 x 8	S	M	PS-Sh	Compact, spreading form, dk green needles/red fruit.
<i>Taxus x media</i> Anglojap Yew 'Densiformis'	3 x 7	S	M	PS-Sh	Dense, rounded form with dk green needles/red fruit.
'Hicksii'	8 x 3	M	M	PS-Sh	Columnar form with dark green needles and red fruit.
'Tauntonii'	3 x 5	S	M	PS-Sh	Dense, wider than tall with dark green needles.

Key:
 Growth Rate: S=slow; M=moderate; F=fast
 Soil Moisture: H=high; M=medium; L=low
 Exposure: S=sun; PS=partial sun; Sh=Shade
 Plant Select® plants may be viewed online at www.plantselect.org

Deciduous Shrubs

Alnus tenuifolia Alder Thinleaf
Amelanchier alnifolia Serviceberry
Amphora canescens Leadplant
Aronia melanocarpa Black Chokeberry
Atriplex canescens Fourwing Saltbush
Berberis Barberry
Buddleia davidi Butterfly Bush
Cargana arborescens Siberian Pea Shrub
Caryopteris x clandonensis "Dark Knight" Dark Knight Spirea
Caryopteris x clandonensis Blue Mist Spirea
Cercocarpus montanus Mountain Mahogany
Cercocarpus intricatus Mahonia Littleleaf Mountain Mahogany
Cercocarpus ledifolius Curl Leaf Mountain Mahogany
Chaenomeles japonica Red Quince
Chamaebatiara millefolium Fernbush
Chrysothamnus nauseosus Rabbit Brush
Chrysothamnus nauseosus nauseosus Dwarf Rabbit Brush
Cornus sericea 'Isanti' Isante Dogwood
Cornus alba 'Argenteo-marginata' Variegated Dogwood
Cornus mas Cornelian Cherry
Cornus sericea 'Bailey' Redtwig Dogwood
Cornus sericea 'flaviramea' Yellow twig Dogwood
Cornus sericea 'Kelsey' Kelsey's Dogwood
Corylus avellana 'Rote Zeller' Filbert - Red Leaf
Cotinus coggygria Purple Smoke Tree
Cotoneaster apiculatus Cranberry Cotoneaster
Cotoneaster dammeri Coral Beauty Cotoneaster
Cotoneaster horizontalis Lowfast Cotoneaster
Cotoneaster lucidus Peking Cotoneaster

Physocarpus opulifolius 'Nanus' Dwarf Ninebark
Potentilla fruticosa 'Golden Drop' Golden Drop Potentilla
Potentilla fruticosa 'Goldfinger' Goldfinger Potentilla

Potentilla fruticosa 'Katherine Dyke' Katherine Dyke Potentilla
Potentilla fruticosa 'McKay's White' McKay's White Potentilla
Potentilla fruticosa 'Tangerine' Tangerine Potentilla
Prunus besseyi Western Sand Cherry
Prunus besseyi 'Pawnee Buttes' Pawnee Buttes Sand Cherry

Prunus fruticosa Flowering Almond
Prunus tomentosa Nanking Cherry
Prunus virginiana Choke cherry Native
Prunus x cistena Cistina Plum

Quercus gambelli Gambel Oak
Quercus unilata Wavyleaf Oak
Rhamnus frangula 'Columnaris' Buckthorn

Rhamnus frangula 'Aspenifolia' Fernleaf Buckthorn
Rhamnus frangula 'Smithii' Smith Buckthorn
Rhus aromatica Gro-low Sumac
Rhus glabra Dwarf Smooth Sumac
Rhus trilobata Threeleaf Sumac
Rhus typhina 'lanciniata' Cutleaf Sumac
Ribes alpinum Alpine Currant
Ribes alpinum 'Greenmound' Greenmound Current
Ribes aureum Yellow Flowering Currant
Ribes uva-crispa 'Comanche' Gooseberry Comanche

Cytisus purgan 'Spanish gold' Spanish Gold Broom
Euonymus alatus compacta Burning Bush – Compact
Euonymus alatus Burning Bush
Euonymus fortunei 'Emerald Gaiety' European Euonymus
Euonymus fortunei radicans 'Harlequin' Euonymus Emerald Gaiety
Euonymus fortunei 'Emerald and Gold' Emerald n'Gold
 Euonymus
Euonymuskiautschovica 'Manhattan' Manhattan Euonymus
Fallugia paridoxa Apache Plume
Forsythia Arnolds Dwarf Arnolds Dwarf Forsythia
Forsythia Arnolds Gold Arnolds Gold Forsythia
Forsythia x intermedia 'Spring Glory' Spring Glory Forsythia
Hibiscus syriacus Rose of Sharon
Hippophae rhamnoides Sea Buckthorn
Hydrangea arborescens 'Annabelle' Flowering Hydrangea
Hypericum kalmanium 'Hidcote' St. John's Wort

Kolkwitzia amabilis Beauty Bush
Ligustrum vulgare 'Cheyenne' Cheyenne Privet
Ligustrum vulgare 'Lodense' Lodense Privet
Lonicera korolkowii v. floribun Honeysuckle Blue Velvet da' BlueVel'
Lonicera xylosteum compactum Honeysuckle - Emerald Mound
Mahonia aquifolium Mahonia
Mahonia aquilolium compacta Compact Mahonia
Perovskia atripiciflora Russian Sage
Philadelphus Virginalis Littleleaf Mockorange
Philadelphus lewisii 'Cheyanne' Cheyenne Mockorange
Philadelphus x Virginalis 'Minnesota snowflake' Minnesota Snowflake Mockorange
Philadelphus x. virginalis Mock orange Virginal
Physocarpus momogynus Mountain Ninebark
Physocarpus opulifolius 'Lutus' Golden Ninebark

Rosa sp. Roses Shrub
Salix purpurea Dwarf Artic Willow
Sambucus canadensis Elder, Golden
Spirea japonica 'Goldflame' Goldflame Spirea

Spirea japonica 'Little Princes' Little Princess Spirea

Spirea japonica 'Froebel' Froebel Spirea
Spirea nipponica Cheyenne Snowmound Spirea
Spirea x bumalda 'Gumball' Gumball Spirea
Spirea x bumalda 'goldmound' Goldmound Spirea
Spirea x bumalda Anthony Waterer Spirea
Symphoricarpos occidentalis Western Snowberry

Symphoricarpus x chenault 'Hancock' Hancock Coralberry

Symphoricarpus x orbiculatus Indian Current/Red Snow Coralberry
Syringa meyeri , 'Palibin's Dwarf Korean Lilac
Syringa patula 'Miss Kim' Miss Kim Lilac

Syringa vilgaris French hybrids Lilac
Syringa vulgaris alba Common White Lilac
Syringa vulgaris Common Purple Lilac
Syringa x chinensi Chinese Lilac
Viburnum opulus 'Nanum' Dwarf European Cranberry
Viburnum lantana Lantana Viburnum
Viburnum trilobum Highbush Cranberry Viburnum

Viburnum trilobum 'Compactum' American Compact Cranberry
Viburnum x burkwoodii Burkwood Viburnum
Yucca baccata Banana Yucca
Yucca filamentosa Filamentosa Yucca

Shrub Roses

Adeleide Hoodless	Nearly Wild
Agnes	Pink Grootendorst
Austrian Copper	Pink Prairie
Bonica	Rugosa
Cuthberg Grant	Sea Foam
F.J. Grootendorst	Sunblaze
Hansa	The Fairy
Heritage	Therese Bugnet
Meidiland Series (several var.)	The Hunter
Morden Centennial	Knockout (All varieties)

Ornamental Grasses

<u>Scientific Name</u>	<u>Common Name</u>
<i>Andropogon gerardii</i>	Big Bluestem
<i>Bouteloua gracilis</i> 'Blonde Ambition'	'Blond Ambition' Blue Grama Grass
<i>Calamagrostis arundinacea</i> 'Karl Forester	Feather Reed- Karl Forester
<i>Chasmanthium latifolium</i>	Northern Sea Oats
<i>Descampsia caespitosa</i>	Tufted Hair Grass
<i>Erianthus ravennace</i>	Pampas Grass
<i>Festuca glauca</i> 'Elijah Blue	Blue Fescue
<i>Helictotrichon sempervirens</i>	Blue Avena / Oat Grass
<i>Imperarata Cylindrica</i> 'rubra'	Blood Grass
<i>Miscanthus sinensis</i> 'Gracillimus'	Maiden Grasses
<i>Misicanthus sinensis</i> 'Zebrinus'	Zebra Grass
<i>Panicum virgatum</i> 'Heavy Metal'	Heavy Metal Switch Grass
<i>Pennistum alopecuroides</i> 'Hameln'	Hardy /Fountain Grass
<i>Phalaris arundinacea</i> 'Pieta'	Ribbon Grass
<i>Schizachyrium scoparium</i>	Little Bluestem

Perennials

<i>Achillea</i> spp. Yarrow	<i>Gypsophila paniculata</i> Baby's breath
<i>Agastache aurantiaca</i> Coronado Hyssop	<i>Hemerocallis</i> spp. Daylily
<i>Agastache cana</i> , <i>Sinning</i> Hyssop Sonoran Sunset	<i>Heuchera sanguinea</i> Coral Bells Snow Angel
<i>Agastache rupestris</i> Sunset Hyssop	<i>Hosta</i> spp. Hosta
<i>Armeria maritime</i> Thrift	<i>Iberis sempervirens</i> Candytuft
<i>Anchusa azurea</i> Anchusa (Italian bugloss)	<i>Iris</i> hybrids Bearded iris
<i>Aquilegia</i> spp. Columbine	<i>Lavandula angustifolia</i> Lavender
<i>Asclepias tuberosa</i> Butterfly weed	<i>Leucanthemum x superbum</i> Shasta daisy
<i>Aster novae-angliae</i> Aster (New England)	<i>Liatris scariosa</i> Gayfeather
	<i>Linum perenne</i> Blue flax
<i>Callirhoe involucrate</i> Winecups	<i>Lobelia cardinalis</i> Cardinal flower
<i>Campanula medium</i> Canterbury bells	<i>Lupinus polyphyllus</i> Lupine
<i>Campanula</i> spp. Harebell	<i>Monarda didyma</i> Beebalm
<i>Centaurea cyanus</i> Cornflower	<i>Oenothera macrocarpa subsp. incana</i> Silverblade, Evening Primrose
<i>Coreopsis lanceolata</i> Coreopsis	<i>Osteospermum barberia</i> var. <i>compactum</i> Purple Mountain Sun Daisy
<i>Crysanthemum morifolium</i> Hardy Mum	<i>Osteospermum</i> Lavender Mist
<i>Delosperma floribundum</i> Starburst Iceplant- Mesa Verde	<i>Paeonia</i> hybrids Peony
<i>Delphinium</i> hybrids Delphinium	<i>Papaver nudicaule</i> Iceland poppy
<i>Dendranthema coccineum</i> Painted daisy	* <i>P. orientale</i> Oriental poppy
<i>Dianthus barbatus</i> Sweet Shalliam	<i>Penstemon</i> spp. Penstemon
<i>Dianthus</i> First Love	<i>Penstemon grandiflorus</i> Prairie Jewel, Pikes Peak Purple, Red Rocks
<i>Diacia integerrim</i>	<i>Phlox paniculata</i> Garden phlox
<i>Dicentra spectabilis</i>	<i>Physostegia virginiana</i> Dragonhead (false)
<i>Coral Canyon Twin Spur</i> Bleeding heart	<i>Rudbeckia hirta</i> Black-eyed Susan
<i>Dictamnus albus</i> Gas plant	<i>Rudbeckia laciniata</i> 'Hortensiana' - Golden glow
<i>Echinacea purpurea</i> Purple coneflower	
<i>Echinacea purpurea</i> white coneflower	<i>Scabiosa caucasica</i> Pincushion flower
<i>Eriogonum umbellatum</i> Sulphur flower	
<i>Fraxinus</i> 'Pink Lipstick'	<i>Sedum</i> spp. Sedum, stonecrop
<i>Gaillardia aristata</i> Gaillardia, blanket flower	<i>Thermopsis rhombifolia</i> Golden banner, false lupine
<i>Gazania linearism</i> Colorado Gold Gazania	<i>Veronica spicata</i> Veronica
<i>Gazania krebsiana</i> Tanager Gazania	<i>Viola corneta</i> Horned violet, viola
<i>Geranium magniflorum</i> Geranium, La Veta Lace	<i>Viola odorata</i> Sweet violet
<i>Geranium sanguineum</i> Bloody Cranesbill	<i>Zauschneria garrettii</i> Orange Carpet Hummingbird Trumpet

Approved Native Trees and Shrubs to be installed to provide erosion control, slope stability, and diversity along drainages in open space areas. Woody plants must be installed no closer than 25 feet from drainage inlets, outlets, or bridges. Native shrubs and trees must be installed along the toe of slope of drainages with adequate hydrologic conditions to support them. Do not plant across the floor of the drainage area.

Common Name	Scientific Name	Variety	Mature Height (feet)	Location
Netleaf hackberry	<i>Celtis reticulata</i>	Native	15 – 35	Drainages, 2 - 4’ above saturated soil
Rabbitbrush	<i>Chrysothamnus nauseosus</i>	Native	3 – 5	Drier areas
Dwarf rabbitbrush	<i>Chrysothamnus nauseosus var. naus.</i>	Native	2	Drier areas
Plains Cottonwood	<i>Populus sargentii</i>	Native	45 – 60	Drainages, 2 - 4’ above saturated soil
Narrowleaf cottonwood	<i>Populus angustifolia</i>	Native	25 – 40	Drainages, 2 - 4’ above saturated soil, plants will spread by root sprouts
Chokecherry	<i>Padus virginiana (aka Prunus)</i>	Native	10 – 12	Drainages, 1 - 5 above
Wild plum	<i>Prunus americana</i>	Native	6 – 8	Drainages 2 - 8’ above saturated soil
Golden current	<i>Ribes aureum</i>	Native	3 – 4	Drainages, 2 - 10’ above saturated soil
Three-leaf sumac	<i>Rhus trilobata</i>	Native	4 – 8	Drier prairie areas and drainages 2+ feet above saturated soils.
Peachleaf willow	<i>Salix amygdaloides</i>	Native	15 – 35	Drainages 1 - 4’ above saturated soil.
Sandbar willow	<i>Salix exigua</i>	Native	5 – 6	Drainages, 0 - 3’ above saturated soil
Snowberry	<i>Symphoricarpos occidentalis</i>	Native	2	Drainages, 2 - 10’ above saturated soil,
Yucca	<i>Yucca glauca</i>	Native	2	Drier prairie sites (north facing slopes preferred).

1063.00 Plant and Tree Handling, Transportation, and Storage

All plants shall be packed, transported, and handled with utmost care to insure adequate protection against injury. Trees shall be protected from extreme temperatures, freezing or extreme heat. Trees shall be transported to the site in a covered vehicle that prevents wind and temperature extremes. Shade cloth shall be used to cover plant materials during transportation to protect the plant canopies and roots from drying winds in transit.

Trees shall be planted as soon as possible. If not planted on the day of delivery all plants shall be placed in a temporary nursery, irrigated daily, shaded and protected from sun or wind. Balled and Burlapped trees shall be heeled in within 24 hours of delivery in a compact group with a suitable mulch material placed around and between the balls so they are completely covered. No

plant shall remain on the job site in temporary storage for over a month unless otherwise approved by the Parks & Recreation Director or designee.

Tree stock will be protected from excessive vibration; avoiding being thrown or bounced off mobile equipment to the ground. Trees shall not be dragged, lifted, or pulled by the trunk or foliage parts in a manner that will loosen the roots in the ball. To avoid damage when setting the tree in the hole, lift the tree with straps or rope around the root ball, not by the trunk.

1064.00 Planting

Location and Spacing of Trees

1064.01 Location Staking

The Contractor is responsible for arranging to have the locations of all utility lines (including but not limited to water, sewer, gas, electrical, phone and irrigation) marked prior to the inspection to assure safety and protection. The Contractor will be required to stake the proposed locations of all trees and shrubs on-site for approval by the Town prior to planting. The Town reserves the right to move, shift or adjust any or all of the stakes to better achieve the planting design intentions as shown on the accepted drawings.

1064.02 Placement

- A. General. All trees shall be placed a minimum of ten (10) feet from all buildings. When space is limited or a special design effect or function is desired, closer spacing can be allowed upon permission of the Parks & Recreation Director or designee.
- B. Near Fire Hydrants. No street trees shall be planted within ten (10) feet of any fire hydrant.
- C. Near Streets, Sidewalks, Alleys, or Curbs. Other than within tree lawns, no tree shall be planted within four (4) feet of any street, sidewalk, alley, or curb, except where authorized by the Parks & Recreation Director or designee. Coniferous trees shall be planted a minimum of six (6) feet away from hardscapes (sidewalks, trails, curbs, fences, walls, columns, parking lots, etc.). Fruit-bearing and thorny trees shall be placed a minimum of ten (10) feet away from parking lots, sidewalks and trails.
- D. Sight Triangles. Regardless of the presence of warning signs, no trees shall be planted within landscape beds or tree lawns located between a sidewalk or curb closer than 55' from the visibility triangle of an intersection unless authorized by the Parks & Recreation Director or designee.
- E. Near Utility Lines. No street trees, other than those species designated as ornamental/small trees in the Town of Erie Approved Tree List, shall be planted under or within ten (10) lateral feet of any overhead electrical, telephone or other utility wire or line, or over or within five (5) lateral feet of any underground water, sewer, electrical, telephone or other utility wire, line or main.
- F. Within Tree Grates: All placement considerations listed above, as well as planting and cultural practices listed within this section also apply to trees planted within tree

grates. Trees grate design must be approved by the TOE Parks & Recreation Director or designee.

- G. Within Tree Lawns: All trees shall be centered within tree lawns unless approved otherwise by the Parks and Recreation Director.

1064.03 Placement of Native Trees and Shrubs in Native Areas.

Native trees and shrubs are to be added to the open space areas in order to help stabilize slopes, provide diversity for wildlife and improved natural aesthetics. One tree or one thicket consisting of 15 shrubs shall be planted along all drainages for each 50 feet of drainage. Trees and thickets may be grouped more closely than 50 feet, if desired for design purposes. Woody riparian plants may be installed no closer than 25 feet from drainage inlets, outlets, or bridges. Native riparian shrubs and trees must be installed along the toe of slope of drainages with adequate hydrologic conditions to support them. Do not plant shrubs and trees across the floor of the drainage, blocking the flow. A Town of Erie representative will assist with field locations, upon request. Please give at least 3 working days' notice prior to planting to obtain assistance with proper tree location in native drainages. If properly located, these native trees and shrubs may be exempted from drip irrigation requirements.

1064.04 Seasons of Planting

Planting may occur whenever the soil conditions are favorable or as authorized by the Parks & Recreation Director or designee. Optimum planting periods are from March 15 to June 15 and from September 1 to October 15. Dormant bare root native shrubs and trees, for planting in open space areas, must be installed while still dormant, from March 1- April 15th.

1064.05 Planting Procedures

Tree Planting Procedures

Tree pits shall be excavated a minimum of two (2) times greater than the diameter of the root ball and shall be saucer shaped. The root flare shall be identified to assure that the hole has been dug to the proper depth—and no more. The planting pit shall be deep enough to allow for the root flare to remain two (2) inches higher than the surrounding finish grade.

If tree pits are dug utilizing mechanical equipment, edges of planting hole shall be flared down to create a saucer shaped planting pit and the sides of the hole shall be scored to prevent glazing or compaction of planting hole and potential obstruction of lateral root growth. Care shall be taken to assure that the holes are the proper depth.

When planting on a sloping site, the root flare shall be even with the grade on the uphill side of the tree. Site soil will need to be added on the downhill side to cover the sides of the root ball and to construct the soil berm to hold water.

All containers shall be removed prior to backfilling. This includes any organic manufactured containers. If the root system of a container grown plant has become container-bound, the entire outer and bottom one (1) inch of the root system shall be shaved prior to planting. Vertically slicing the root system shall not be utilized as a substitution for root shaving.

The root ball shall be placed on firm, undisturbed soil in the planting pit to prevent settling.

Remove wire baskets in their entirety. Remove the bottom of the wire basket first, prior to setting in hole. Adjust the root ball into the planting pit to check for desired depth. All plants shall be set plumb and straight and in the center of the pits and faced for best effect. After the tree has been correctly positioned in the planting pit, remove the sides of the wire basket. All wire, burlap, twine, string, etc. shall be removed from the

Planting pit backfill mixture shall consist of two (2) parts of excavated native soil and one (1) part organic soil amendment. Organic amendments shall be as specified in Section 1062.02. Backfill mixture shall be thoroughly blended to homogeneous condition in specific area away from plant excavations.

Backfill the hole 1/3 full to thoroughly stabilize the lower part of the root ball at planting to keep the root ball from shifting. Fill the remainder of the hole by adding the soil a few inches at a time and settle with water. Continue this process until the hole is filled and the tree is firmly planted. The tree will be thoroughly watered to fill any voids and eliminate air pockets. Do not backfill over crown of the root ball.

A soil berm (water ring) can be constructed around trees to serve as temporary irrigation for trees only if the trees will be watered with a hose or other high volume device. Soil berms should not exceed a height and width of 3 to 4 inches. Soil berms shall be removed and graded once permanent irrigation has been installed.

All plant tags, flagging tape, labels, string, etc. shall be removed from the trunk and canopy.

Shrub Planting Procedures

Prior to the planting of Perennial or Groundcover plants, the Contractor will cultivate the area to be planted to a depth of six (6) inches so as to free the site of weeds. All stones, sticks, and debris brought to the surface over one and one-half inches (1 ½) in diameter will be removed from the site. Prior to planting, the Contractor will uniformly apply the specified organic material at the rate of five (5) cubic yards per one thousand (1,000) square feet. And then incorporate both materials into the soil to a depth of six (6) inches with a disc, rototiller, or other suitable tilling equipment.

All containers shall be removed prior to backfilling. This includes any organic manufactured containers. If the root system of a container grown plant has become container-bound, the roots shall be cut vertically on a minimum of two sides of the root mass prior to planting.

All plant tags, flagging tape, labels, string, etc. shall be removed.

The Contractor shall install Perennial or Groundcover plants taking note of required on-center spacing and required distances from edges. Plants will be planted within the amended soil, 1” (inch) above finished grade. A layer of weed barrier fabric will be installed, and three (3) inches of specified mulch will be placed over it. All seams in the fabric will overlap a minimum of twelve (12) inches. All perennial or groundcover beds will have a continuous layer of weed barrier fabric installed under the mulch. Landscape fabrics shall be as specified in Section 1062.03

The Contractor shall insure that all Perennial or Groundcover beds are watered as necessary until establishment is achieved.

The diameter of all shrub planting pits shall be twelve (12) inches greater in diameter than the diameter of the container. Shrub pits shall be excavated so that the top of the ball shall be one (1) inch above finish grade.

1064.06 Staking and Guying

All deciduous and coniferous trees will be staked and guyed immediately after they are planted. The position of the stakes shall be oriented with regards to prevailing winds. Staking for deciduous trees must be done using two (2) six (6) foot steel T-posts driven perpendicular to the tree at 180 Degrees. Staking for coniferous trees must be done using three (3) two (2) foot steel T-posts driven at 120 Degrees. All stakes shall be driven outside of the root ball and in undisturbed soil. All exposed ends of T-posts shall be capped with vinyl/plastic T-post caps. The tree shall be secured to the T-post using flat, woven polypropylene w/900 pound (or greater) break strength, and shall be green in color. Examples include DeepRoot, ArborTie7 or other Town-approved equivalent). Stakes shall remain on deciduous trees for one (1) year and on coniferous trees for two (2) years. Contractor is responsible for periodically re-tensioning and the removal of tree stakes. Staking materials shall be as specified in Section 1062.06.

1064.07 Mulching

1064.07.01 Trees

Upon completion of the planting operations, the Contractor shall prepare tree pits and planter beds for mulch. All deciduous trees shall have a sod-free base at least four (4) feet in diameter and evergreens shall have a sod-free base extending to the drip line. Mulch shall be placed evenly in the saucer to the depth of three (3) inches and a minimum of four (4) feet in diameter. Mulch shall be

placed two (2) inches from and not make contact with tree trunks. In specific cases, when approved by the Parks & Recreation Director or designee, rock mulch may be substituted for the fibrous mulch. Mulch shall be as specified in Section 1062.01.

1064.07.02 Shrub Beds

In areas where plants are grouped into beds, or in areas where gravel, rock or wood mulch is to be used as a ground cover, the entire bed will be excavated to a depth of three (3) inches, a layer of weed barrier fabric will be installed, and three (3) inches of suitable ground cover, such as wood mulch or rock, will be placed over it. Different mulch types shall be separated by three-sixteenths (3/16) inch wide by six (6) inches deep green painted steel. All seams in the fabric will overlap a minimum of twelve (12) inches. Landscape fabric pins will be used a minimum of every three feet along the edge of the fabric as well as a minimum of three feet on center throughout the fabric. All shrub beds will have a continuous layer of weed barrier fabric installed under the mulch. Landscape fabrics shall be as specified in Section 1062.03.

1064.08 Pruning

All pruning shall comply with ANSI A300 standards shall only be performed by an I.S.A. Certified Tree Worker, Arborist or Municipal Specialist and shall be done with clean, sharp, sterile tools. Pruning shall be limited to the removal of dead, diseased, broken, and damaged limbs or twigs at the time of planting.

All necessary corrective pruning shall be performed after a full season of growth in the new location by a trained professional. All plant materials will be pruned to preserve its natural form and character and in a manner appropriate to its particular requirements. Pruning shall be the responsibility of the Contractor. Contractor shall remove and replace excessively pruned or malformed stock resulting from improper pruning.

1064.09 Fertilizing

Trees and shrubs shall not be fertilized during installation or for the first twelve (12) months following installation.

1065.00 Maintenance

1065.01 Pruning

All tree pruning shall comply with ANSI A300 standards and shall only be performed by an I.S.A. Certified Tree Worker, Municipal Specialist or Arborist. Contractor shall remove and replace excessively pruned or malformed stock resulting from improper pruning. All necessary corrective pruning shall be performed after a full season of growth in the new location. All plant materials will

be pruned to preserve its natural form and character and in a manner appropriate to its particular requirements. All plant material shall be kept maintained free of dead, diseased, broken and damaged limbs or wigs. Pruning shall be the responsibility of the Contractor.

1065.02 Replacements

All replacement plant materials shall be the responsibility of the Contractor until final acceptance has been granted. Refer to Quantity and Quality of Plant Material (sec. 1068.02)

Replacement of plant materials shall occur at the following rate:

Type	1 Year	2 Years
Deciduous Tree	Increase caliper by one (1) inch	Increase caliper by one and one-half (1 ½) Inch
Evergreen Tree	Increase height by one and one-half (1 ½) foot	Increase height by two(2) feet

1065.03 Fertilization

Trees and shrubs shall not be fertilized during installation or for the first twelve (12) months following installation.

1065.04 Watering

The Contractor shall ensure that all plant materials are watered as necessary until final acceptance has been granted.

All plant materials shall be given supplemental water as required throughout the winter months.

1065.05 Staking

All deciduous trees shall be staked for twelve (12) months and evergreen trees for twenty –four (24) months. Contractor is responsible for periodically re-tensioning and the removal of tree stakes throughout this period. Refer to Staking and Guying (sec 1064.06)

1065.06 Weeding

All tree wells, shrub and perennial beds, and areas where gravel, rock or wood mulch is to be used as a ground cover shall be kept free of grass, weeds and other contaminates until final acceptance has been granted.

1065.07 Mulching

Contractor is responsible for maintaining adequate (3”) mulch depth for the duration of the warranty period.

1068.00 Inspections

Inspections shall be completed in accordance with Section 1024.00, Inspections, of these STANDARDS AND SPECIFICATIONS. The Contractor must notify the Town for inspections of plant location staking, plant materials, and planting operations.

1068.01 Plant Location Staking

The Town will inspect the plant location stakings prior to the installation of any plant materials as specified in Section 1064.01, Location Staking, of these STANDARDS AND SPECIFICATIONS.

1068.02 Quantity and Quality of Plant Material

The Town will inspect the plant material following their delivery to the site and prior to the planting on the site. The Town reserves the right to reject any plant not meeting the accepted design requirements for size, shape, form and conditions at that time.

All new and replacement plant materials require inspection and shall be tagged by the Parks & Recreation Director or designee for all Town of Erie maintained areas prior to planting. Contact appropriate Town of Erie staff to arrange for materials to be tagged.

Substitutions – Any changes in species and plant locations shall be submitted to Town of Erie inspectors for review and approval. Overall quality and design concept to be consistent with approved landscape plan.

1068.03 Planting Operations

The Town will inspect the planting operations, including digging, planting, pruning, fertilizing and mulching.

1069.00 Final Acceptance and Final Inspection

For all landscape and irrigation projects, please see and follow the Final Acceptance procedures (Section 240), Final Inspection procedures (Sections 241-243) and Final Acceptance procedures for public improvements contracted by the Town (Sections 250-253) of the Town’s most current Standards and Specifications.

1070.00 PARK AMENITIES AND PLAYGROUND EQUIPMENT

1071.00 General

Selection of recreation equipment and park amenities must be approved by the Parks & Recreation Director or designee prior to purchase by the Contractor. In selecting equipment and amenities, the brand, style, color, size and other criteria will be considered and selected by the Town. All installations of equipment and amenities will be done by the Contractor.

1072.00 Softball and Baseball Field Specifications

Adequate drainage must be taken into account in ballfield designs. Infield slopes will be between one half (1/2) percent and one (1) percent. Outfield slopes will be between one (1) percent and two (2) percent.

1072.01 Softball

1072.01.01 Infield Dimensions

Infields shall be cut on a sixty-five (65) foot arc from the front center of the pitching plate. Home plate shall be twenty-five (25) feet from the backstop, and the foul line shall be twenty-five (25) feet from wing fences. Pitching plate anchors shall be installed at forty feet (40'), forty-three feet (43'), forty-six feet (46') and fifty feet (50') from the rear point of home plate, measured to the front center of the pitching rubber. Base anchors will be set to accommodate base path lengths of sixty feet (60'), sixty-five feet (65'), and seventy feet (70'). All other dimensions related to base paths shall conform with United States Specialty Sports Association standard field dimension standards. Distances from home plate to second base shall be measured from the back point of home plate to the center of second base.

1072.01.02 Infield Composition

The infield area will be excavated four (4) inches below grade. Subgrade will be laser graded prior to infield material installation. Four (4) inches of suitable infield mixture consisting of approximately seventy (70) percent sand and thirty (30) percent clay/silt with eight (8) pounds Stabilizer™ organic binder and eighty (80) pounds of Turface MVP calcined clay infield conditioner per ton shall be installed. Infield mixture will be installed, laser graded, and compacted to a firm, smooth surface according to manufacturer's specifications. All mixtures will be approved by the Parks & Recreation Director or designee prior to installation.

1072.02 Baseball

1072.02.01 Infield Dimensions

Skinned infields shall be cut on a ninety-five foot (95') arc from the center of the pitching plate. Home plate shall be fifty feet (50') from the backstop with foul lines a minimum of thirty-five feet

(35') from wing fences. Pitching plate anchors shall be installed at thirty feet (30'), forty feet (40'), forty-six feet (46'), fifty feet (50'), and sixty feet six inches (60'6") from the rear point of home plate, measured to the front center of the pitching plate. Base anchors will be set to accommodate base path lengths of forty-five feet (55'), sixty feet (60'), sixty-five feet (65'), seventy feet (70'), and ninety feet (90'). One pitching plate shall be installed at a distance chosen by the Parks & Recreation Director or designee. Distances from home plate to second base shall be measured from the back point of home plate to the center of second base.

Grass infields with raised mounds shall be designed and constructed to accepted industry standards. Base anchor and pitching anchor distances shall be approved by the Parks & Recreation Director or designee

1072.02.02 Infield Composition

The skinned infield area will be excavated four (4) inches below grade. Subgrade will be laser graded prior to infield material installation. Four (4) inches of suitable infield mixture consisting of approximately seventy (70) percent sand and thirty (30) percent clay/silt with eight (8) pounds Stabilizer™ organic binder per ton shall be installed. Infield mixture will be installed, laser graded, and compacted to a firm, smooth surface according to manufacturer's specifications. All mixtures will be approved by the Parks & Recreation Director or designee prior to installation.

1072.03 Sports Equipment

The following products shall be used during installation. Any other products must be reviewed by Parks & Recreation Director or designee to be accepted as equal.

1072.03.01 Softball and Baseball Equipment

Any substitutions of the following materials must be approved by the Parks & Recreation Director or designee to be accepted as equal

A. Anchors

- a. Anchors shall be constructed of a single one and one half (1 ½) inch square, corrosion resistant coated, square, Schutt™ Hollywood style sleeve centered inside a eight (8) inch square by eight inch (8) by eight (8) inch half cinder block. Concrete shall be cured for twenty-four (24) hours prior to final installation.
- b. Anchors placed on the first base line shall be constructed of a Schutt™ Hollywood Double Stanchion (or approved equivalent), able to accommodate the use of a Schutt™ Hollywood Impact Double First Base, centered inside a five inch (5') by five inch (5') by twenty-one inch (21") concrete form. Concrete shall be cured for twenty-four (24) hours prior to installation.
- c. Anchor shall be installed to allow for the anchor sleeve to be one and one half (1 ½) inches below finished grade at completion.

Accepted models of ground anchor mounts: Schutt™, model #12916550, for single anchor applications or Schutt™, model # 12920705, for double anchor applications (or approved equivalent)

B. Bases

- a. Bases shall be Schutt™ Jack Corbett Hollywood bases, model #12901010 (or approved equivalent)

C. Pitching Rubbers

- a. Pitching rubbers shall be Schutt™ Hollywood Double Stanchion style, model # 12920706, regulation 6 inch (6”) by 24 inch(24”) (or approved equivalent)

D. Home Plate

- a. Home Plates shall be Bolco™ permanent in ground style, 3 inch thick, with ¾ inch wood bottom (or approved equivalent)

1072.03.02 Soccer Equipment

Any substitutions of the following materials must be approved by the Parks & Recreation Director or designee to be accepted as equal.

- A. Soccer goals shall be JayPro™ (or approved equivalent) with square face, white powder coated, and an aluminum frame
- B. Goals equal to or larger in width than 18 feet, 6 inches - shall also have a Jaypro™ (or approved equivalent) cross-bar and wheel transport kit
- C. Goal anchors shall be auger style that utilize plastic coated metal cord as means of securing goal to auger anchor
- D. Nets shall be made of five and one half (5 ½) inch square mesh made of a minimum three (3) mm twisted twine, white in color

1073.00 Playground Equipment

1073.01 Proposal Submittals

The manufacturer’s representative shall provide the following items and information to the Town with each playground proposal:

- A. Complete three-dimensional drawings of equipment.
- B. Individual components specifications and schematic drawings of the play system.

- C. A minimum of three (3) references for similar work recently completed to the Town. Each reference shall include a brief summary of work completed, location, the owner’s representative name and phone number.
- D. A schedule of work that includes the time it will take to order and receive the play equipment and the time it will take to install once the play equipment is delivered.
- E. Playground installer must provide documentation of current NPSI Certified Playground Safety Inspector (CPSI) certification.
- F. Playground installer must provide documentation of current certification in playground construction by either a) NPCAI Playground Construction School and/or b) by the selected equipment manufacturer.
- G. A letter from the manufacturer stating that the playground equipment will meet or exceed the latest CPSC Guidelines and the ASTM F-1487-07ae1 Standards. Letters from the manufacturers must reference the model number or drawing numbers of each unit.
- H. Copies of warranty information for play equipment to the Town. Warranties shall include minimum: ten (10) years on posts and decks; five (5) years on plastic; ten (10) years on clamps, and one (1) year on all other parts.

1073.02 Accessibility Requirements

Playgrounds shall comply with the Department of Justice (DOJ) 2010 Standard for Accessible Design where applicable.

1073.03 Protective Ground Space Area

The play system layout for each site shall include a safety surface area surrounded by a protective barrier. The Protective Surfacing within the use zone of each play structure must meet or exceed ASTM F-1292-09 and ASTM F-1951-09b, where applicable. A sub-surface drainage system shall be installed under each protective surface area. The design of the drainage system must be approved in writing by the Parks & Recreation Director or their designee.

1073.03.01 Approved Protective Surfacing

- A. The following surface materials may be used when installed in accordance with ASTM F1292-09, ASTM F1951-09b, ASTM 1487-11.
 - a. Engineered Wood Fiber mulch
 - b. Poured in place resilient matting
 - c. Unitary rubber tiles
- B. Any other form of protective surfacing must be approved by the Parks & Recreation Director or designee.

1073.03.02 Prohibited Protective Surfacing

- A. The following surface materials, in addition to those failing ASTM 1292-09, may not be used as a protective surfacing.
 - a. Pea gravel
 - b. Sand
 - c. Shredded recycled rubber mulch

The composition of the barrier for protective ground space area shall be approved by the Parks & Recreation Director or designee.

1073.04 Component Requirements

- A. All protective barriers, handrails, and guard rails shall meet requirements of ASTM F-1487-07ae1.
- B. Upper body equipment shall meet requirements of ASTM F-1487-07ae1.
- C. All equipment shall come with an structural integrity test results from the manufacturer.
- D. Platforms, Landings, Walkways, Ramps, and similar Transitional Play surfaces shall meet requirements of ASTM F-1487-07ae1.

The following requirements for equipment components apply:

- A. Slides must be double walled except for tube slides.
- B. Components of the play system(s) for specific sites shall be approved by the Town. Each play system shall include and not be limited to: roofs, climbers, slides, bridges, ladders, arches, overheads, play panels, transfer points, decks, barriers, guard rails, protective barriers, and swings.
- C. Component colors must be approved by the Public Works or designee.
- D. Wear mats shall be installed at all entrances and exits of composite structures, slide exits, and swing bay areas; excluding bucket swing bays. When used in conjunction with engineered wood fiber, mats shall be installed six inches (6") below the finish surfacing level.
 - a. Three feet by three feet (3' x 3') mats are required for composite structures entrances and exits.
 - b. Six feet by three feet (6'x3') mats are required for belt swing centered under each belt swing.

1073.05 Play Equipment**1073.05.01 New Play Equipment**

- A. New play equipment will be built of durable materials resistant to degradation. All steel decks must have a punched surface and all steel surfaces shall have a baked polyester powder coating finish.
- B. All plastics and other materials that experience ultraviolet (UV) degradation shall be protected against UV and shall be Polyvinyl Chloride (PVC) free.

- C. Contractor shall provide all necessary posts, kickplates, fittings, clamps, railings, protective barriers, fasteners, and other fixtures as necessary to complete the structure, as indicated on the construction drawings.
- D. All play components used must meet current applicable ASTM standards: specifically ASTM 1487-11, and 2010 DOJ Standard for Accessible Design where applicable.

1073.05.02 Prohibited Play Equipment

The following play equipment items are prohibited, in addition to those not meeting ASTM 1487-11:

- A. Metal slides of any dimension and shape, regardless of finishing
- B. Log rolls
- C. Equipment constructed of wood

1073.06 Site Requirements

1073.06.01 Protection

The Contractor shall be responsible for the protection of the play area site during the construction process. It is required that a temporary chain link security fence a minimum of six feet (6') high be installed around the perimeter of all playgrounds from the start of construction through project final acceptance.

1073.06.02 Damages

Any damages to the play structure, play elements, hardware, surfacing or any other element associated with playground installation shall be paid for at the Contractor's expenses.

1073.07 Inspections

Inspections shall be completed in accordance with Section 1024.00, of these standards and specifications. The Contractor must notify the Parks & Recreation Director or designee for inspection of drainage installation prior to surfacing installation.

1073.07.01 Play Environment inspection

An audit of the play area must be conducted by a third party National Playground Safety Institute (NPSI) Certified Playground Safety Inspector (CPSI), at the expense of the Contractor, to verify compliance. If any non-compliance issues are identified during this process these issues must be addressed and appropriate action taken, at the expense of the Contractor, to bring items into compliance. All components of the play environment must be in compliance prior to final acceptance.

1073.08 Maintenance and Training

The Contractor shall develop and conduct a training program to allow the Town maintenance personnel to become knowledgeable with the play equipment. Training shall include, but not be limited to: proper routine and preventative maintenance practices, common issue associated with play features, and how to optimize use of features. The Contractor shall also supply surfacing maintenance guidelines.

The Contractor shall provide wrenches or other tools needed to adjust or replace vandal resistant fasteners. The Contractor shall also provide primer and touch-up paints. Paints and primers shall be colors that match the structures and shall be compatible with the structure’s powder coat finishing.

The Contractor shall provide a complete parts manual.

1073.09 Warranty

The following minimum warranties are required for all playground equipment:

- A. Ten (10) year warranty on all steel posts, clamps and decks against structural failure due to natural corrosion, deterioration, or workmanship.
- B. Five (5) year warranty for structural failure of plastic or rubber components.
- C. Three (3) year warranty for structural failure of all spring equipment.
- D. One (1) year warranty for structural failure of moving parts, and any other materials not covered by the above mentioned warranties.
- E. All other site furnishings: Warranty all products and workmanship for one year or manufacturer’s warranty, whichever is greater, beyond the date of final acceptance.

1074.00 Pocket Park Design Standards

Developed Pocket Parks are required to include a combination of the following components, according to the formula in the above section.

List A – Infrastructure – (All Required)

- 1. Benches (two minimum).
- 2. Bicycle Racks (min. to serve four bikes).
- 3. Dog pick up station.
- 4. Identification sign (clearly specifying contact number for maintenance or other concerns).
- 5. Individual shelter with two picnic tables.
- 6. Irrigation.
- 7. Open turf area (min. size 3,000 sf, max size 15,000 sf).
- 8. Sidewalks (ADA accessible).

9. Trash receptacles (minimum of two).
10. Plant Materials:
 - a. Five (5) deciduous trees.
 - b. Three (3) ornamental trees.
 - c. Two (2) evergreen trees.
 - d. Twenty (20) shrubs.
 - e. Twenty four (24) perennials.
 - f. Three (3) ornamental grasses.

List B – Pre selected components – (Select 2)

1. Display garden.
2. Group picnic shelter (min. size 500 sf and four tables in place of individual shelter in List A).
3. Loop walk (min. length 2,000 lf).
4. Natural area (min. size 10,000 sf).
5. Multi-level play structure.

List C – Components of Choice – (Select 3)

If not selected in list A or B

1. Loop walk (min. length 2,000 lf – if not used as a pre-selected component).
2. Natural area – min. size 10,000 sf (if not used as pre-selected component).
3. Multi-level play structure (if not used as pre-selected component).
4. Individual shelters with two tables (in addition to shelter in List A or group shelter in List B).

Additional components:

5. Basketball (one full court).
6. Bocce ball.
7. Boulder play area or climbing structure.
8. Community garden.
9. Fitness course.
10. Handball.
11. Horseshoe pits.
12. Open turf sculpted as a play berm, mound or hill with a minimum three-foot height.
13. Other play features that include swings, spring toys, sand play, dramatic play, tetherball, etc. (include at least three).
14. Outdoor classroom to seat 20.
15. Public art.
16. Shuffleboard.
17. Tennis.

- 18. Volleyball.
- 19. Water spray ground.
- 20. Water feature (A passive, water-based amenity such as fountains, ponds, or waterfalls).
- 21. Or equivalent component as approved by Town of Erie.

List D – Comfort and Convenience Features – (Select 2)
All may be counted only once, except as noted

- 1. BBQ grills (min. one per every two tables).
- 2. Benches (min. two per acre, in addition to benches in List A).
- 3. Drinking fountain (may include dog bowl attachment).
- 4. Electricity and lighting to shelter for night use (counted one per item).
- 5. Landscaping (results in double the ‘List A’ landscaping requirements).
- 6. Picnic tables (in addition to those in List A, B, or C).
- 7. Shade structures for components from List B or C (other than List B shelters) counted one per item.

1080.00 TRAILS, WALKWAYS AND MAINTENANCE PATHS

1081.00 Concrete Trails, Walkways and Maintenance Paths

All sidewalks and maintenance paths within the parks, open space, or greenbelts, which could be utilized by the general public for conveyance, will be a minimum of eight (8) feet wide and six (6) inches thick concrete and shall have fiber mesh included in the mix. The concrete shall have minimum twenty-eight (28) day compression strength of four thousand (4,000) pounds per square inch (PSI) and shall meet all applicable requirements of Section 400.00, Concrete Work, of these STANDARDS AND SPECIFICATIONS.

1082.00 Soft Trails

Soft trails will conform in accordance with the Standard Drawings unless otherwise approved by the Parks & Recreation Director or designee.

1083.00 Trail Specifications

1083.01 Location of Trails

To the extent possible, trails should be located, configured and set back from natural creeks or bodies of water so that recreation use will not significantly impact native plant and animal habitat, or be damaged by high water events.

1083.02 Alignment of Trails

Trails should be generally sinuous in nature, avoiding overlong and straight runs greater than 300 feet. A two foot (2') change from centerline, alternating from side to side every one hundred feet (100') is the standard used by the Town.

1083.03 Width of Trail Corridor

Spaces used to accommodate trails should be generally no less than three (3) times the width of the trail and shall accommodate development of Americans with Disabilities Act (ADA) compliant trails.

1083.04 Requirement for Flared Ends at Intersecting Trail Connections

At each trail intersection, there shall be a flared end to assist maintenance vehicles, pedestrians and cyclists in navigating the turn. At ninety (90) degree intersections, a three foot (3') flare shall be placed. For more information, see the Stand Detail sheet which shows this requirement. If not clearly shown on approved construction drawings, trails which intersect at an orientation other than ninety (90) degrees will be field-fitted to create an appropriate flared trail connection.

1083.05 Crusher Fines Specifications

Crusher fines shall be gold or grey colored, depending upon project requirements. 100% of crusher fines are to pass through a 1/4" screen; no larger material shall be included within the crusher fines mixture. The mixture should be approximately 25% pebbles (screen sizes >#4 and <#10); 35% grit (screen sizes >10 and <100); and 40% dust (screen sizes >#100 and <#270). Vendor must supply a material sample for approval by the Parks and Recreation Director & Recreation Director, as well as a written composition analysis showing the sieve size and amount of material retained within each sieve.

1083.06 Use of Stabilized vs. Unstabilized Crusher Fines

Normally, unstabilized crusher fines are adequate for most trail applications. However, if pathway (or a portion of the pathway) is to be located within an area that is subject to a 1% or greater probability of flooding in any one year (100 year flood plain or greater), than polymer-stabilized crusher fines are to be used. Suitable polymers include Soiltac, StaLoc, and NaturalPave (or equivalent). Vendor must supply a material sample for approval by the Parks & Recreation Director or designee, as well as a written composition analysis showing the sieve size and amount of material retained within each sieve, as well as the polymer content. Petroleum-based polymer products are unacceptable and will be rejected.

1084.00 Types of Trails**1084.01 Spine Trail**

Spine Trails consist of a wide concrete trail (8'-10') with an attached crusher fines trail (4'). In areas with low water conditions that may experience regular flooding, a ten foot (10') concrete trail may substitute for the standard spine trail configuration of a concrete trail with an attached crusher fines trail.

- A. A.1. Shoulders maximum slope 1:6.
A.2. The cross slope across travel surface shall not exceed 2%.
- B. Soft surface width – 4' crusher fines with geo textile fabric underlayment.
B.1. Shoulders must be a minimum width of 2', with up to 6' preferred.
B.2. Slope along the direction of travel not to exceed 5%.
- C. All spine trails must meet ADA standards.
- D. Minimum trail corridor width 30 – 40' or greater preferred.
- E. Trails shall be designed to minimize crossings of streets and other hazards.
- F. On grade street crossings will be clearly marked with signage and cross-walks. Must conform to American Association of State Highway & Transportation Officials (AASHTO) Standards.
- G. Stop signs shall be installed at all street crossings.
- H. Prefer on grade street crossings at intersections rather than mid-block.
- I. Trails shall be located away from nuisance areas such as oil and gas facilities, dangerous ditches, steep slopes and mining areas that include tailings and shafts.
- J. Minimum overhead clearance shall be 10'. Minimum side clearance shall be 8' from edge of trail.
- K. Spine trails shall be designed to accommodate maintenance vehicles such as pick up trucks and utility vehicles for routine all weather maintenance.
- L. Locate spine trails in open space areas whenever possible.
- M. Avoid locations which impact native plant and animal habitat.
- N. Where the path is located next to a steep drop off or embankment, an ADA-compliant railing with a minimum height of 36" and/or a 5' separation between the trail and top or bottom of embankment is required.
- O. Minimum turning radius for 20 mph trails shall be 100 ft, 25 mph trails 156 ft, 30 mph trails 225 ft. In cases where substandard curve radius is unavoidable curve warning signs and centerline striping shall be used.
- P. Stormwater and drainage control shall be installed to prevent standing water, soil accumulation, moss and algae on trail surface.
- Q. Adequate sight distance at curves and intersections must be maintained. Must conform to AASHTO Standards.
- R. General design speed of 20 mph should be used for all spine trails.
- S. Follow AASHTO Guide for the Development of Bicycle Facilities.

1084.02 Local Trails

- A. Local trail width equals the width of the spine trail to which it connects.
- B. Local trails are made of concrete, using the specifications shown above in 1084.01.

- C. At no time will the width of a local trail be less than 6’.
- D. Slope across trail not to exceed 2%.
- E. Slopes along direction of travel not to exceed 5%.
- F. Trails should be located away from nuisance areas, including above ground oil and gas facilities, pipelines, dangerous ditches, steep slopes, and mining areas that include tailings and shafts.
- G. All local trails must meet ADA Standards.
- H. Local trails shall be designed to accommodate maintenance vehicles.
- I. Adjacent slopes, grades and separations shall comply with those described under Spine Trails (section 1084.01).
- J. Minimum overhead clearance shall be 10’; minimum side clearance shall be 8’.

1084.03 Primitive Trails

- A. Primitive trails shall be located away from steep slopes, sensitive habitat and natural areas and nuisance areas.
- B. Minimum width shall be no less than 4’.
- C. Primitive trails shall consist of stabilized crusher fines with geo textile fabric underlayment.
- D. Erosion control components shall be installed at appropriate locations.
- E. Adjacent slopes, grades and separations shall comply with those described under Spine Trails (section 1084.01)
- F. Minimum overhead clearance shall be 10’; minimum side clearance shall be 8’.

1084.04 Trailheads

- A. Trailheads shall be provided where primary trail routes converge and where access from street to parking is convenient.
- B. Adequate number of parking spaces is required based upon projected use of trailhead including the required number of parking spaces meeting current ADA guidelines, including hard surfacing, signage, ramps, detectable warnings, etc.
- C. Adequate location and informational signage is required at trailhead, including trail name and map and ordinances. Signage must comply with Town of Erie sign specifications and include town logo.
- D. Trash containers shall be provided, number based upon projected use. Containers must be of an approved design, be anchored, expanded metal, and covered to exclude animals.
- E. Pet Waste stations shall be provided that match to current model in use by Parks & Recreation Department.
- F. Benches and tables shall be provided based on projected use. 6’ expanded metal and surface mounted on concrete pad.
- G. All amenities shall be ADA accessible and selected for durability and vandal resistance, consistency of color, material and form. All amenities shall be approved by the Parks and Recreation Director & Recreation Director or designee.

- H. Portable restrooms in a permanent enclosure may be installed as appropriate using MZI enclosures or approved equivalent.

1084.05 Waysides

- A. Located every ½ mile.
- B. Will include 6' benches or tables of expanded metal which shall be surface mounted on concrete pad. Tables should be ADA accessible.
- C. Adequate number of seating elements based on projected trail use.

1084.06 Bridges

- A. All bridge designs must be stamped as certified by a licensed Engineer and be approved by the Public Works Director or designee.
- B. Director or designee.
- C. Bridges must meet all current ADA accessibility guidelines.
- D. Bridges shall be of steel construction.
- E. Bridges shall have a minimum clear width of 10'.
- F. Bridges must accommodate a minimum load weight of 10,000 pounds for maintenance vehicles. Depending upon location, higher load weights may be required.
- G. Concrete floors are preferred. Wood or TREX-type recycled plastic lumber may be acceptable, but must be approved in writing by the Parks & Recreation Director or designee.
- H. Bridges must conform to all current standards, including the AASHTO Guide Specifications for Design of Pedestrian Bridges, the AASHTO Standard Specifications for Highway Bridges, and the CDOT Standard Specifications for Road and Bridge Construction

1090.00 PARKS AND TRAIL SIGN SPECIFICATIONS**1091.00 General**

The purpose of the signage and way finding guidelines contained in the Town of Erie Parks & Trail Sign Program is to provide standards for exterior signs and to establish a consistent and controlled program. Use of consistent design, color, materials, products, logo typography and size relations helps visually unify all signs. Parks and trail signage must be approved by the Parks & Recreation Director or designee prior to fabrication and installation on Town owned and maintained properties. The Town has a signage program and complete design guidelines are available by contacting Parks & Recreation Administration or the Town Clerk. Sign function and usage varies and most of these variations have been anticipated and categorized in the program guidelines. Sign requirements vary from location to location and the examples shown in the sign program manual may not address every situation, but will assist in selecting the appropriate sign type and format for a particular situation.

This section is not intended to be an all-inclusive listing of signage. Additional signage may be considered based upon integrity of the proposal and consistency with Town signage program and/or fundamental nature of trail or park.

1092.00 Sign Types

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk) for detailed specification and construction details for the sign types listed in the remainder of this section.

1092.01 Identification

Identification signs are intended for pedestrians and/or vehicular traffic. The signs identify corresponding park, trail, Town logo or other information as determined by the Town. Note: Park or trail hours, rules and regulations shall not be posted on identification signs.

1092.01.01 Specific Identification sign types:

- Sign Type A: Park Entry Identification
- Sign Type B: Trailhead / Trail Access Identification
- Sign Type C: Primary Building Identification
- Sign Type D: Secondary Building Identification
- Sign Type E: Park Feature Identification

1092.02 Informational, Instruction and Interpretive

Informational, Instructions and Interpretive signs are intended for pedestrians. The signs identify the corresponding feature, any instructions related to use of the feature and/or historic or nature-based interpretive narratives and other information as determined by the Town.

1092.02.01 Specific Informational, Instruction and Interpretive sign types:

- Sign Type F: Shelter Reservation Instructions
- Sign Type G: Tennis Court Lights Instructions
- Sign Type H: Push/Pull
- Sign Type J: Primary Interpretive
- Sign Type K: Secondary Interpretive
- Sign Type L: Trail Mile Marker

1092.03 Regulatory

Regulatory signs are intended for pedestrians and list rule and regulations for the corresponding park, trail or other amenity. These signs may be freestanding or fence mounted as appropriate.

1092.03.01 Specific Regulatory sign types:

- Sign Type M: Primary Park Rules, Freestanding
- Sign Type N: Primary Park Rules, Wall/Fence Mounted
- Sign Type O: Secondary Rules, Freestanding and Wall/Fence Mounted
- Sign Type P: Trail Rules, Freestanding
- Sign Type Q: Trail Rules, Fence Mounted
- Sign Type R: Primary Regulatory, Freestanding
- Sign Type S: Primary Regulatory, Wall/Fence Mounted
- Sign Type T: Portable Regulatory
- Sign Type Z: Trail Regulatory

1092.04 Way Finding

Way Finding signs are intended for pedestrians and provide directional information that may include an orientation map. Other information may be included as determined by the Town. These signs may be freestanding or fence mounted as appropriate.

1092.04.01 Specific Way Finding sign types:

- Sign Type U: Park Map/Directory
- Sign Type V: Trailhead Map
- Sign Type W: Primary Pedestrian Way Finding, Multiple Messages
- Sign Type X: Secondary Pedestrian Way Finding, Single Messages
- Sign Type Y: Trail Way Finding

1093.00 Typefaces

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk).

1094.00 Color Palette

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk).

1095.00 Color Groupings by Type/Area

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk).

1096.00 Graphic Standards

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk).

1097.00 Fabricator Performance and Material Requirements

Please refer to the Town of Erie Parks & Trail Sign Program Manual (available from Parks & Recreation Administration or Town Clerk).